

DEFERRED SUBMITTALS

- FIRE PROTECTION SYSTEM
- FIRE ALARM SYSTEM
- ROOF TRUSS DESIGN



REFERENCED CODES

CODES, 2019 CALIFORNIA BUILDING STANDARDS CODE (CAL. CODE REGS., TITLE 24) COMPLIANCE WITH CITY OF CAMERON PARK, EL DORADO COUNTY MUNICIPAL CODES. CALGREEN CALIFORNIA GREEN BUILDING STANDARDS CODE (CALGREEN), PART 11 OF TITLE 24 CBC CALIFORNIA BUILDING CODE (PART 2 OF TITLE 24) 2019 CALIFORNIA RESIDENTIAL CODE AND CALIFORNIA FIRE CODE. CCR CALIFORNIA CODE OF REGULATIONS CEBC CALIFORNIA EXISTING BUILDING CODE (PART 10 OF TITLE 24) CEC CALIFORNIA ELECTRICAL CODE (PART 3 OF TITLE 24) CEC CALIFORNIA ENERGY CODE (PART 6 OF TITLE 24) CEC CALIFORNIA ENERGY COMMISSION CMC CALIFORNIA MECHANICAL CODE (PART 4 OF TITLE 24) CPC CALIFORNIA PLUMBING CODE (PART 5 OF TITLE 24) CRSC CALIFORNIA REFERENCED STANDARDS CODE (PART 12 OF TITLE 24) DPH IDENTIFIES CODE PROVISIONS BY THE DEPARTMENT OF PUBLIC HEALTH IBC INTERNATIONAL BUILDING CODE IFC INTERNATIONAL FIRE CODE IEBC INTERNATIONAL EXISTING BUILDING CODE IRC INTERNATIONAL RESIDENTIAL CODE NEC NATIONAL ELECTRICAL CODE NFPA NATIONAL FIRE PROTECTION ASSOCIATION

THE GENERAL CONTRACTOR SHALL FULLY COMPLY WITH THE FOLLOWING INTERNATIONAL

DRAWING INDEX



VICINITY MAP

PROJECT DESCRIPTION

NEW MULTI-FAMILY DWELLING. 14 UNITS 2 BED & 2 BATH SINGLE FAMILY TOWN HOUSES.

PROJECT INFORMATION

PROPERTY ADDRESS:

2580 COUNTRY CLUB DRIVE CAMERON PARK, CA 95628

LEGAL DESCRIPTION:

LOT 32, CAMERON PARK NORTH NO. 5

MAPS D- 93 EL DORADO COUNTY

ZONING CLASSIFICATION:

R-1-8 MULTI-FAMILY RESIDENTIAL ZONE

APN: 082-391-002

OCCUPANCY GROUP:

R-1 (SEC. 130.24.030)

CONSTRUCTION TYPE: TYPE V-B

REQUIRED SETBACKS/HEIGHT LIMITS:

FRONT YARD: 20'

MIN. SIDE YARD: 5'

MIN. REAR YARD: 10'

MAX. BUILDING HEIGHT: 50'

LOT SIZE: 24578 SF = 0.56 ACRES

TOTAL HABITABLE AREA: 16100 SF

FLOOR AREA RATIO (FAR):

16100/24578 X100 = 65.5%

PROJECT DIRECTORY

Owner: KASSIS DEVELOPMENT

2580 COUNTRY CLUB DRIVE CAMERON PARK, CA 95682

Tel: (916) 802-6331

Architect: PIXELARCH, LTD., ARCHITECTURE AND CIVIL,

STRUCTURAL & MECHANICAL ENGINEERING 24001 CALLE DE LA MAGDALENA, UNIT 3896

LAGUNA HILLS, CA 92653 TEL: 415 316 7162 info@pixelarchltd.com

PE on board: BARRETT CROOCK PE

barrettcrook@kittyhawkengineering.com

Energy Consult LLC (424) 247-7658 www.title24ez.com



KASSIS DEVELOPMENT
2580 COUNTRY CLUB DRIVE CAMERON PAR
EL DORADO COUNTY

vision Notes:	
te	Description

COPYRIGHT
THIS DRAWING IS AN INSTRUMENT OF
SERVICE AND AS SUCH, REMAINS THE
PROPERTY OF PIXELARCH LTD. PERMISSION
FOR USE OR REPRODUCTION IS LIMITED AND
CAN BE EXTENDED ONLY BY WRITTEN
PERMISSION WITH OWNER, PIXELARCH LTD.

COVER SHEET

cale:

Date: JAN. 19, 2023

Page No.:

- 1. THE GENERAL CONDITIONS OF THE CONTRACT FOR CONSTRUCTION, A.I.A. STANDARD FORM A201 - CURRENT EDITION, ARE HEREBY INCORPORATED INTO THIS DOCUMENT EXCEPT AS SPECIFICALLY MODIFIED BELOW.
- 2. THE CONTRACTOR SHALL SECURE AND PAY FOR THE BUILDING PERMIT AND OTHER PERMITS AND GOVERNMENTAL FEES. LICENSES AND INSPECTIONS NECESSARY FOR PROPER EXECUTION AND COMPLETION OF THE WORK. SCHEDULING OF APPROVALS AND INSPECTIONS BY AUTHORITIES HAVING JURISDICTION (A.H.J.) OVER THE WORK IS THE RESPONSIBILITY OF THE CONTRACTOR.
- 3. THE CONTRACT DOCUMENTS CONVEY DESIGN INTENT AND THE GENERAL TYPE OF CONSTRUCTION DESIRED ARE INTENDED TO APPLY TO THE FINEST QUALITY OF CONSTRUCTION, MATERIAL AND WORKMANSHIP THROUGHOUT.
- 4. ANY ITEMS NOTED "BY OWNER" OR AS BEING PROVIDED BY OWNER IN THESE CONTRACT DOCUMENTS SHALL BE PROVIDED BY THE OWNER OR HIS VENDORS AND INSTALLED BY THE GENERAL CONTRACTOR OR HIS FORCES UNLESS EXPRESSLY NOTED AS BEING INSTALLED "BY OWNER" - REFER TO THE RESPONSIBILITY SCHEDULE FOR MORE INFORMATION. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ANY AND ALL ACCESSORY MATERIALS REQUIRED TO INSTALL SUCH ITEMS AND MAKE FINAL CONNECTIONS.
- 5. PRIOR TO SUBMITTING A PROPOSAL OR COMMENCEMENT OF WORK, THE CONTRACTOR SHALL VISIT THE PROJECT SITE TO COMPARE THE SCOPE OF WORK SHOWN ON THE DRAWINGS AND OTHER CONTRACT DOCUMENTS WITH EXISTING CONDITIONS. PROMPTLY REPORT ANY ERRORS, OMISSIONS, INCONSISTENCIES OR OTHER DETRIMENTAL CONDITIONS TO THE ARCHITECT. IF THE CONTRACTOR FAILS TO PERFORM THIS OBLIGATION, THE CONTRACTOR WILL BE RESPONSIBLE FOR ALL COSTS AND DAMAGES ASSOCIATED WITH ACTIONS REQUIRED TO CORRECT UNREPORTED CONDITIONS THAT OTHERWISE COULD HAVE BEEN AVOIDED.
- 6. IN THE EVENT THAT DISCREPANCIES ARE FOUND BETWEEN DRAWINGS AND/OR SPECIFICATIONS, THE CONTRACTOR SHALL REQUEST A CLARIFICATION FROM THE ARCHITECT IN WRITING. THE ARCHITECT'S RESPONSE TO THE CONTRACTOR'S REQUEST FOR INFORMATION SHALL NOT BE CAUSE FOR A CHANGE IN THE CONTRACT AMOUNT UNLESS IT IS AGREED THAT THE ORIGINAL SCOPE OF WORK HAS BEEN ALTERED BY THE
- 7. ALL CONSULTANT DRAWINGS ARE SUPPLEMENTAL TO THE ARCHITECTURAL DRAWINGS. IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO COORDINATE WITH THE ARCHITECTURAL DRAWINGS BEFORE THE INSTALLATION OF ANY OF THE CONSULTANTS WORK AND TO BRING ANY DISCREPANCIES OR CONFLICTS TO THE ARCHITECTS ATTENTION FOR CLARIFICATION. IMPROPERLY INSTALLED WORK SHALL BE CORRECTED BY THE GENERAL CONTRACTOR AT HIS EXPENSE AND AT NO EXPENSE TO THE ARCHITECT, HIS CONSULTANTS OR THE OWNER.
- 8. GENERAL CONTRACTOR WILL COORDINATE ALL WORK WITH THE LANDLORD AND PERFORM WORK TO MEET ALL REQUIREMENTS OF THE LEASE AGREEMENT. CONTRACTORS WORK IS SUBJECT TO INSPECTION BY THE LANDLORD FOR COMPLIANCE WITH THE TERMS OF THE LEASE AGREEMENT.
- 9. PRIOR TO BEGINNING WORK, THE CONTRACTOR SHALL FURNISH A CONSTRUCTION SCHEDULE SHOWING THE CHRONOLOGICAL PHASES OF WORK, SCHEDULE OF VALUES, AND INSURANCE CERTIFICATE. THIS SCHEDULE SHALL INDICATE ORDERING LEAD TIMES, A BEGINNING AND END DATE FOR EACH PHASE AND A PROJECTED COMPLETION DATE FOR THE ENTIRE PROJECT.
- 10. THE CONTRACTOR IS WHOLLY RESPONSIBLE FOR THE COORDINATION AND SCHEDULING OF THE WORK EFFORTS FOR ALL ENGINEERS, SUBCONTRACTORS, CRAFTSMEN AND TRADESMEN REQUIRED TO COMPLETE THE JOB AND SHALL BE RESPONSIBLE FOR PROVIDING THEM WITH FULL SETS OF CURRENT DRAWINGS, ADDENDUM, AND OTHER SUPPLEMENTAL INFORMATION PERTINENT TO THE COMPLETION OF THE WORK.
- 11. CONTRACTOR SHALL COORDINATE THE INSTALLATION OF THE VARIOUS TRADE ITEMS STRUCTURAL MEMBERS, CONDUITS, RACEWAYS, LIGHT FIXTURES, CEILING SYSTEM AND ANY SPECIAL STRUCTURAL SUPPORTS REQUIRED) AND SHALL BE RESPONSIBLE FOR MAINTAINING THE FINISH CEILING HEIGHT ABOVE THE FINISH FLOOR INDICATED IN THE DRAWINGS AND THE FINISH SCHEDULE.
- 12. THE CONTRACTOR SHALL PROVIDE TEMPORARY LIGHTING AND ELECTRICAL SERVICE FOR TRADES.
- 13. UNLESS OTHERWISE STIPULATED IN THE CONTRACT DOCUMENTS, THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROVISION, STORAGE AND PAYMENT OF ALL LABOR, MATERIALS, TAXES, EQUIPMENT, TOOLS, CONSTRUCTION EQUIPMENT, MACHINERY, TRANSPORTATION AND OTHER FACILITIES NECESSARY FOR PROPER EXECUTION AND COMPLETION OF THE WORK WHETHER OR NOT IT IS SPECIFICALLY CALLED OUT OR DETAILED ON THE DRAWINGS.
- 14. THE CONTRACTOR WARRANTS TO THE OWNER THAT MATERIALS AND EQUIPMENT FURNISHED UNDER THE CONTRACT WILL MEET INDUSTRY STANDARDS AND BE NEW AND OF GOOD QUALITY UNLESS OTHERWISE PERMITTED BY THE CONTRACT DOCUMENTS. THE WORK WILL BE INSTALLED PER MANUFACTURER'S SPECIFICATIONS, FREE FROM DEFECTS AND WILL BE COMPLETED IN A NEAT AND WORKMANLIKE MANNER ACCEPTABLE TO THE OWNER.
- 15. THE CONTRACTOR SHALL PROMPTLY CORRECT IN A PROFESSIONAL MANNER, AT NO COST TO THE OWNER AND WITHOUT CHANGE IN CONTRACT TIME, ALL NON-CONFORMING OR DEFECTIVE WORK AND DAMAGES CAUSED BY HIS WORK OR WORKMEN WHETHER DISCOVERED BEFORE OR AFTER SUBSTANTIAL COMPLETION.
- 16. THE CONTRACTOR SHALL INSPECT ALL EQUIPMENT AND SYSTEMS FOR PROPER OPERATIONS UPON SUBSTANTIAL COMPLETION OF PROJECT.
- 17. THE CONTRACTOR SHALL THOROUGHLY CLEAN THE ENTIRE PROJECT SITE AND
- 18. THE GENERAL CONTRACTOR SHALL PROVIDE THE FOLLOWING REPORTS AND

ADJACENT AFFECTED SPACES TO THE SATISFACTION OF THE OWNER.

- GUARANTEES TO THE OWNER OR OWNER'S REPRESENTATIVE: A. ELECTRICAL INSPECTOR'S CERTIFICATE OF COMPLIANCE WITH A.H.J.
- REQUIREMENTS. B. PLUMBING INSPECTOR'S CERTIFICATE OF COMPLIANCE WITH A.H.J. REQUIREMENTS
- C. FIRE MARSHALL'S CERTIFICATE OF COMPLIANCE WITH A.H.J. REQUIREMENTS.
- D. BUILDING INSPECTOR'S CERTIFICATE OF COMPLIANCE WITH A.H.J. REQUIREMENTS.
- E. HEALTH DEPARTMENT CERTIFICATE OF COMPLIANCE WITH A.H.J. REQUIREMENTS.
- F. A.H.J. CERTIFICATE OF OCCUPANCY.
- B. DRAWING CONVENTIONS
- 1. DIMENSIONS TAKE PRECEDENCE OVER SCALE ON THE CONSTRUCTION DRAWINGS. NOTIFY THE ARCHITECT OF DISCREPANCIES BETWEEN DRAWING DIMENSIONS AND FIELD CONDITIONS.
- 2. PLAN DIMENSIONS ARE GIVEN TO FACE OF STUDS OR FACE OF EXISTING WALL OR FACE OF NEW FIRE-RATED WALL UNLESS OTHERWISE NOTED.
- 3. PARTITION THICKNESS IS DERIVED FROM DESCRIPTION OF THE PARTITION CONSTRUCTION AND/OR DESIGNATED DETAIL

- 4. PARTITIONS THAT INTERSECT INTERIOR OR EXTERIOR GLAZED WALLS ARE TO CENTER ON MULLIONS AND PERPENDICULAR TO EXTERIOR WALL UNLESS DETAILED OTHERWISE.
- 5. UNLESS OTHERWISE NOTED, PARTITIONS AND OTHER ELEMENTS ON THE DRAWING THAT ARE DRAWN AT AN OBLIQUE ANGLE ARE TO BE CONSTRUCTED AT A 45-DEGREE ANGLE TO THE MAIN GRID.
- 6. WALLS SHOWN ALIGNED WITH BASE BUILDING STRUCTURE SHALL BE FLUSH AND SMOOTH WITH BASE BUILDING STRUCTURE UNLESS OTHERWISE NOTED.
- 7. UNLESS DIMENSIONED OTHERWISE, DEPTH OF FURRING ON COLUMNS AND OTHER ELEMENTS IS TO BE HELD TO THE MINIMUM THICKNESS REQUIRED TO CONCEAL MECHANICAL, PLUMBING OR ELECTRICAL COMPONENTS.
- 8. UNLESS OTHERWISE INDICATED, POSITION DOOR JAMBS 4" OFF THE FACE OF ADJACENT INTERSECTING PARTITIONS OR CENTER ON PARTITION.
- 9. OUTLETS THAT OCCUR ON OPPOSITE SIDES OF THE SAME PARTITION ARE TO BE STAGGERED HORIZONTALLY A MINIMUM OF 12" TO MINIMIZE SOUND TRANSMISSION.
- C. DEMOLITION, CUTTING, AND PATCHING
- 1. THE CONTRACTOR SHALL INSPECT THE SITE AND CALL ATTENTION TO ENVIRONMENTAL HAZARDS WITH LANDLORD. SAID HAZARDS ARE TO BE REMOVED AT THE LANDLORD'S EXPENSE. REMOVAL SHALL ADHERE TO THE ENVIRONMENTAL PROTECTION AGENCY'S GUIDELINES.
- 2. THE CONTRACTOR IS RESPONSIBLE FOR ALL DEMOLITION, CUTTING AND PATCHING REQUIRED TO FACILITATE COMPLETION OF THE WORK.
- 3. PRIOR TO STARTING WORK, ERECT TEMPORARY BARRIERS AROUND THE PERIMETER OF THE PROJECT AND BASE BUILDING TOILET FACILITIES TO PREVENT THE SPREAD OF DUST AND OTHER CONTAMINANTS TO ADJACENT AREAS OF THE BUILDING. MAINTAIN DUST PROOF AND SOUND BARRIERS THROUGHOUT THE COURSE OF CONSTRUCTION OR UNTIL NO LONGER REQUIRED. REMOVE BARRIERS AND REPAIR ANY DAMAGE CAUSED BY THEIR INSTALLATION TO MATCH ADJACENT SURFACES.
- 4. UNLESS NOTED OTHERWISE, ALL DEMOLISHED DEBRIS, MATERIAL, EQUIPMENT AND FIXTURES BECOME THE PROPERTY OF THE CONTRACTOR WHO IS RESPONSIBLE FOR ITS SAFE REMOVAL FROM THE SITE. DISPOSAL OF DEMOLISHED MATERIAL SHALL BE IN ACCORDANCE WITH APPLICABLE RULES, REGULATIONS AND ORDINANCES OF AUTHORITIES HAVING JURISDICTION. COORDINATE WITH LANDLORD.
- 5. PATCH ALL EXISTING OR NEWLY DAMAGED AREAS TO MATCH ADJACENT SURFACES IN QUALITY, TEXTURE AND COLOR.
- 6. CONTRACTOR IS RESPONSIBLE FOR COORDINATION OF ALL TRENCHING AND UNDER GROUND WORK WITH SUBCONTRACTORS.
- D. GENERAL CONSTRUCTION
- 1. CONTRACTOR SHALL VERIFY ALL GRID LINE COORDINATES AND CHECK THEM AGAINST DIMENSIONS SHOWN ON PLANS AND DETAILS. ARCHITECT SHALL BE NOTIFIED OF ANY DISCREPANCY DURING STAKING.
- 2. ALL LANDSCAPE MATERIALS DISPLACED OR DISTURBED AS A RESULT OF CONSTRUCTION SHALL BE REPLACED OR REPAIRED TO ORIGINAL CONDITION.
- 3. THE CONTRACTOR SHALL FIRMLY ANCHOR PARTITIONS PER JURISDICTION AND INDUSTRY STANDARDS AND USE METAL TRIM ACCESSORIES AT EXPOSED CORNERS. EDGES AND ENDS IN PLASTER AND DRYWALL PARTITIONS.
- 4. PROVIDE FIRE RETARDANT TREATED WOOD BLOCKING FOR ALL WALL MOUNTED PLUMBING FIXTURES, TOILET ACCESSORIES, CABINETS, AND TABLES.
- 5. ALL CONCEALED PLYWOOD, WOOD BLOCKING, AND WOOD STUD/JOIST FRAMING SHALL MEET U.L. FIRE RETARDANT TREATED REQUIREMENTS.
- 6. ALL MATERIALS USED IN UNFINISHED ATTIC SPACE SHALL BE NON-COMBUSTIBLE. ANY WOOD SHALL BE FIRE RETARDANT TREATED.
- 7. DO NOT PUNCH OR USE METAL DECK TO SUPPORT SUSPENDED CEILING. SUSPENDED METAL FRAMING-CEILING AND METAL STUD PARTITION FRAMING SHALL BE SUPPORTED FROM STRUCTURAL STEEL ROOF FRAME.
- 8. ALL ROOF PENETRATIONS SHALL BE CUT, FLASHED AND SEALED BY THE LANDLORD'S ROOFING CONTRACTOR IN ORDER TO MAINTAIN THE ROOF SYSTEM INTEGRITY AND
- 9. THE CONTRACTOR SHALL PROVIDE ACCESS PANELS REQUIRED FOR MECHANICAL. ELECTRICAL AND PLUMBING INSTALLATIONS PER LOCAL BUILDING CODES. LOCATIONS SHALL BE COORDINATED WITH ARCHITECT PRIOR TO INSTALLATION.
- 10. CEILING FRAMING IN THE FIELD SHALL BE SQUARE, LEVEL AND PERFECTLY ALIGNED WITH EACH OTHER AND WITH THE RECESSED LIGHT FIXTURES. ALL RECESSED FIXTURES SHALL BE SET FLUSH INTO CEILING.
- 11. NEW PIPE, CONDUIT AND DUCT PENETRATIONS OF FIRE RATED ASSEMBLIES ARE TO BE CONSTRUCTED IN ACCORDANCE WITH AN UNDERWRITERS LABORATORY TESTED
- 12. WIRING AND CONDUIT IS TO BE CONCEALED IN BOTH NEW AND EXISTING PARTITIONS WITH ALL OUTLETS, SWITCHES AND SIMILAR DEVICES MOUNTED IN RECESSED JUNCTION BOXES WITH FLUSH COVER PLATES. SURFACE MOUNTED CONDUIT, WIREMOLD, OUTLETS, ETC. WILL NOT BE PERMITTED UNLESS OTHERWISE
- 13. VERIFY EXACT DIMENSIONS OF ALL OWNER SUPPLIED EQUIPMENT, FEATURES AND FIXTURES TO ASSURE A PROPER FIT WHERE EQUIPMENT, FEATURES AND FIXTURES ARE SHOWN BUILT-IN TO NEW MILLWORK, UNDER COUNTER AND BETWEEN NEW AND **EXISTING PARTITIONS.**
- 14. COMMUNICATION, DATA, SECURITY AND SIMILAR SYSTEMS WILL BE PROVIDED AND INSTALLED BY THE OWNER UNLESS OTHERWISE NOTED IN THE CONTRACT DOCUMENTS. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO COORDINATE WITH THE OWNER' AND PROVIDE CONDUIT, BOXES AND OTHER ROUGH-IN REQUIREMENTS TO FACILITATE FINAL WIRING INSTALLATION.
- 15. LOCKSETS SHALL BE "KEYED" IN ACCORDANCE WITH OWNER REQUIREMENTS. "KEYS" ARE TO BE DELIVERED TO OWNER PROPERLY TESTED. THE NUMBER OF MASTER AND PASS KEYS SHALL BE COORDINATED WITH LANDLORD.
- 16. PROVIDE STANDARD IDENTIFICATION PLATE WITH OWNER NAME AND SPACE DESIGNATION/ADDRESS AS SPECIFIED THROUGH A COMMON MANUFACTURER BY THE LANDLORD. IF NO LANDLORD STANDARD PROVIDED, PROVIDE A STANDARD 3" X 9" LAMINATED PLASTIC, DARK COOL GRAY COLORED FACE WITH WHITE LETTERING ROUTED INTO FACE. FASTENED TO OWNER REAR EXIT SERVICE DOOR ON THE ACCESS CORRIDOR FACE.
- 17. PROVIDE WATER RESISTANT GYPSUM BOARD AT ALL TILE LOCATIONS, PLASTIC PANEL LOCATIONS, MECHANICAL ROOM WALLS, AND AS NOTED ON DRAWINGS.
- 18. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COMPLYING WITH LOCAL V.O.C. REGULATIONS FOR MATERIALS USED IN CONSTRUCTION.
- 19. SPACES BEING SURFACED SHALL BE CLOSED TO TRAFFIC AND OTHER WORK DURING THE LAYING OF FLOORING, STONE, WOOD, OR OTHER MATERIAL. FINISHED FLOORS SHALL BE COVERED AFTER INSTALLATION FOR PROTECTION.

E. FIRE / LIFE SAFETY

REQUIREMENTS

- 1. ALL REQUIRED PERMITS AND APPROVALS MUST BE OBTAINED FROM THE FIRE DEPARTMENT BEFORE BUILDINGS ARE OCCUPIED.
- 2. MAINTAIN THE FUNCTION AND INTEGRITY OF EXISTING FIRE, LIFE/SAFETY AND SECURITY SYSTEMS.
- 3. PROVIDE OCCUPANCY SIGNS CONFORMING TO APPLICABLE BUILDING CODE
- 4. PROVIDE ADDITIONAL EXIT SIGNS AND FIRE EXTINGUISHERS IN TYPE, NUMBER AND LOCATION AS DIRECTED BY THE FIRE DEPARTMENT FIELD INSPECTOR.
- 5. DURING CONSTRUCTION THE GENERAL CONTRACTOR SHALL PROVIDE A PORTABLE FIRE EXTINGUISHER WITH A RATING OF NOT LESS THAN 2-A WITHIN (75 FT.) FOOT TRAVEL DISTANCE TO ALL PORTIONS OF THE BUILDING ON EACH FLOOR
- F. REQUIRED APPROVALS AND SUBMITTALS
- 1. WHERE THE TERMS "OR EQUAL", "SIMILAR", OR OTHER GENERAL QUALIFYING TERMS ARE USED, IT SHALL BE UNDERSTOOD THAT REFERENCE IS MADE TO THE RULING AND JUDGMENT OF THE ARCHITECT AND MUST BE SUBMITTED FOR APPROVAL PRIOR TO PURCHASE OR USE.
- 2. THE CONTRACTOR SHALL HAVE (10) WORKING DAYS FROM AWARD OF THE CONTRACT TO SUBMIT SUBSTITUTIONS OF SPECIFIED PRODUCTS OR WORK FOR REVIEW BY ARCHITECT AND SHALL INCLUDE CUT SHEETS WITH SPECIFICATIONS AND REASONS FOR SUBSTITUTION. THE ARCHITECT SHALL RESPOND IN (10) WORKING DAYS FROM RECEIPT OF SUBMITTAL. NO SUBSTITUTIONS SHALL BE ACCEPTED AFTER THE INITIAL TIME LIMIT
- 3. THE CONTRACTOR SHALL REVIEW, SIGN, DATE AND SUBMIT A MINIMUM OF (3) SETS OF COMPLETE AND DETAILED SHOP DRAWINGS, FINISHES, FIXTURE AND EQUIPMENT CUT SHEETS TO ARCHITECT FOR REVIEW. THE ARCHITECT SHALL HAVE (10) WORKING DAYS TURNAROUND TIME FROM RECEIPT OF SUBMITTAL. ALL SHOP DRAWINGS AND CUT SHEETS SIGNED "REVIEWED" SHALL SUPERSEDE ORIGINAL DRAWINGS IN DESIGN APPEARANCE ONLY. CONTRACTORS SHALL ASSUME RESPONSIBILITY FOR ERRORS IN
- 4. IN THE EVENT THAT THE AFOREMENTIONED DRAWINGS, SPECIFICATIONS, ETC. ARE NOT SUBMITTED FOR REVIEW AND APPROVAL, THE CONTRACTOR SHALL ASSUME FULL RESPONSIBILITY FOR THE REPLACEMENT, CORRECTION OR ACQUISITION OF PRODUCTS TO COMPLY WITH OWNER'S SPECIFICATION AND APPROVAL
- 5. THE CONTRACTOR SHALL PROVIDE CHALK LINES ON THE SLAB OF PARTITIONS FOR APPROVAL PRIOR TO FRAMING AND SHALL NOTIFY ARCHITECT OF ANY DEVIATION FROM CONSTRUCTION DIMENSIONS OR CLEARANCES AS DESIGNATED ON THE DRAWINGS OR OF APPARENT CONSTRUCTION CONFLICTS.
- 6. UPON SUBSTANTIAL COMPLETION OF WORK, THE HVAC SYSTEM SHALL BE BALANCED BY A QUALIFIED ENGINEER AND A WRITTEN REPORT SHALL BE SUBMITTED TO THE
- 7. UPON SUBMISSION OF THE "FINAL APPLICATION FOR PAYMENT", THE CONTRACTOR SHALL PROVIDE THE OWNER WITH (1) SET OF AS-BUILT DOCUMENTATION INCLUDING DRAWINGS, SPECIFICATIONS, ADDENDA, CHANGE ORDERS, PRODUCT DATA, EQUIPMENT WARRANTIES AND MANUALS, FINISH SAMPLES AND OTHER REQUIRED SUBMITTALS. THE CONTRACTOR SHALL PROVIDE THE OWNER WITH A WRITTEN WARRANTY COVERING ALL WORK PERFORMED UNDER THE CONTRACT, WARRANTY SHALL BE FOR A PERIOD OF ONE YEAR COMMENCING ON THE DATE OF SUBSTANTIAL COMPLETION AND SHALL BE INCLUDED WITH THIS SUBMITTAL.
- 8. THE CONTRACTOR SHALL SUPPLY LIEN WAIVERS RELATING TO ALL WORK WITH THE "FINAL APPLICATION FOR PAYMENT" TO BE REVIEWED FOR "FINAL CERTIFICATE OF

G. CHANGES IN WORK

- 1. THE OWNER WITHOUT INVALIDATING THE CONTRACT, MAY ORDER EXTRA WORK OR MAKE CHANGES BY ALTERING, ADDING TO OR DEDUCTING FROM THE WORK - THE CONTRACT SUM BEING ADJUSTED ACCORDINGLY. SUCH WORK SHALL BE EXECUTED UNDER THE CONDITIONS OF THE ORIGINAL CONTRACT EXCEPT THAT ANY CLAIM FOR EXTENSIONS OF TIME CAUSED THEREBY SHALL BE INDICATED ON THE CHANGE ORDER.
- 2. CLAIMS FOR ADDITIONAL WORK WILL BE SUBMITTED IN WRITING FOR REVIEW BY OWNER AND SHOULD INCLUDE A COMPLETE DESCRIPTION OF THE WORK, MATERIALS BEING USED, THE ROOM NUMBER OR AREA AFFECTED, AND THE AUTHORIZATION UNDER WHICH THE WORK IS BEING PERFORMED.

H. SITE CONSIDERATIONS

- 1. DEMOLITION WORK SHALL BE COORDINATED WITH THE LANDLORD TO MINIMIZE DISRUPTION AND INCONVENIENCE TO OTHER OWNERS IN OCCUPIED BUILDINGS. MAINTAIN SAFE MEANS OF ACCESS AND EGRESS TO OCCUPIED OWNER SPACES.
- 2. PROVIDE CONCRETE FLOOR SLAB THROUGHOUT "LEAVE-OUT" AREA IN BACK OF HOUSE - MATCH EXISTING FLOOR CONSTRUCTION; COORDINATE WITH LANDLORD.
- 3. MAINTAIN THE INTEGRITY OF RATED PARTITIONS AND OTHER FIRE RATED ASSEMBLIES, REPAIR OR REPLACE DAMAGED PORTIONS WITH NEW CONSTRUCTION TO MATCH EXISTING AND HAVE REPAIR WORK APPROVED BY THE BUILDING INSPECTOR.
- 4. THE GENERAL CONTRACTOR SHALL REVIEW THE OWNER'S SPACE WITH THE LANDLORD TO DETERMINE IF ANY ACCESS PANELS ARE LOCATED IN THE OWNER'S SPACE FOR THE LANDLORD'S AND/OR OTHER OWNER ELECTRICAL BOXES AND/OR VALVES. THE GENERAL CONTRACTOR SHALL PROMPTLY NOTIFY THE ARCHITECT AND THE OWNER OF ANY REQUIRED ACCESS PANEL LOCATIONS.
- 5. BUILDING MECHANICAL AND ELECTRICAL SERVICE SHUT DOWN REQUIRED FOR THIS WORK SHALL BE SUBMITTED IN WRITING BY THE CONTRACTOR A MINIMUM OF (72) HOURS IN ADVANCE OF THE SHUT DOWN. THE CONTRACTOR SHALL OBTAIN APPROVAL FROM AUTHORITIES HAVING JURISDICTION PRIOR TO SHUT DOWN AND SHALL NOT OVERLY INCONVENIENCE BUILDING OCCUPANTS.
- 6. VERIFY EXISTING SPRINKLER DROP LOCATIONS (IF ANY). ADDITIONS, MODIFICATIONS OR RELOCATIONS OF THE EXISTING SPRINKLER SYSTEM ARE TO BE ALTERED IN TOTAL CONFORMANCE WITH LANDLORD'S CRITERIA AND SHALL BE SUBMITTED FOR PERMIT SEPARATELY. DRAWINGS SHALL BE SUBMITTED TO LANDLORD FOR REVIEW AND SUBMITTED SEPARATELY TO THE FIRE MARSHAL FOR PERMIT.
- 7. SPRINKLER HEADS AT STOREFRONT AND DISPLAY WINDOWS MUST BE FLUSH TYPE WITH COVER PLATES PAINTED TO MATCH THE ADJACENT CEILING COLOR. DINING AND KITCHEN MUST HAVE SEMI-RECESSED HEADS WITH ESCUTCHEON RINGS PAINTED TO MATCH THE ADJACENT CEILING COLOR.
- 8. WOOD CASEWORK SHALL CONFORM TO ARCHITECTURAL WOODWORK INSTITUTE (AWI) "PREMIUM GRADE" QUALITY STANDARDS AND SHALL BE "FLUSH OVERLAY" CONSTRUCTION UNLESS DETAILED OTHERWISE ON THE DRAWINGS.
- 9. PLASTIC LAMINATE CASEWORK SHALL CONFORM TO ARCHITECTURAL WOODWORK INSTITUTE (AWI) "CUSTOM GRADE" QUALITY STANDARDS AND SHALL BE "FLUSH OVERLAY" CONSTRUCTION UNLESS DETAILED OTHERWISE ON THE DRAWINGS.
- 10. CASEWORK SHALL BE SCRIBED TO WALL OR CEILING. CONTRACTOR SHALL COORDINATE WITH OTHER INVOLVED TRADES.

EGRESS NOTES

- 1. EXIT SIGNS SHALL BE INTERNALLY OR EXTERNALLY ILLUMINATED.
- 2. EXIT SIGNS ILLUMINATED BY AN EXTERNAL SOURCE SHALL HAVE AN INTENSITY OF NOT LESS THAN 5 FOOT CANDLES (54LUX).
- 3. INTERNALLY ILLUMINATED SIGNS SHALL BE LISTED AND LABELED AND SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND SECTION
- 4. EXIT SIGNS SHALL BE ILLUMINATED AT ALL TIMES.

FOOT-CANDLE AT THE WALKING SURFACE.

- 5. EXIT SIGNS SHALL BE CONNECTED TO AN EMERGENCY POWER SYSTEM THAT WILL PROVIDE AN ILLUMINATION OF NOT LESS THAN 90 MIN. IN CASE OF PRIMARY POWER LOSS (1011.2-1022.5.3)
- 6. EGRESS DOORS SHALL BE READILY OPENABLE FROM THE EGRESS SIDE WITHOUT THE USE OF A KEY OR SPECIAL KNOWLEDGE OR EFFORT. SEE 1008.1.8.3 FOR EXCEPTIONS
- 7. DOOR HANDLES, LOCK AND OTHER OPERATING DEVICES SHALL BE INSTALLED AT A MIN. 34" AND A MAX. 48" ABOVE THE FINISHED FLOOR.
- 8. "THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED" SIGN REQUIRED.
- 10. THE MEANS OF EGRESS, INCLUDING THE EXIT DISCHARGE, SHALL BE ILLUMINATED
- AT ALL TIMES THE BUILDING SPACE SERVED BY THE MEANS OF EGRESS IS OCCUPIED. 11. THE MEANS OF EGRESS ILLUMINATION LEVEL SHALL NOT BE LESS THAN 1

9. ALL EGRESS DOOR OPERATION SHALL ALSO COMPLY WITH SECTION 1008.1.9 -

- 12. THE POWER SUPPLY FOR MEANS OF EGRESS ILLUMINATION SHALL NORMALLY BE PROVIDED BY THE PREMISES' ELECTRICAL SUPPLY. IN THE EVENT OF POWER SUPPLY FAILURE, AN EMERGENCY ELECTRICAL SYSTEM SHALL AUTOMATICALLY ILLUMINATE THE
- FOLLOWING AREAS:; A. AISLES AND UNENCLOSED EGRESS STAIRWAYS IN ROOMS AND SPACES THAT
- REQUIRE TWO OR MORE MEANS OF EGRESS B. CORRIDORS, EXIT ENCLOSURES AND EXIT PASSAGEWAYS IN BUILDING
- REQUIRED TO HAVE TOW OR MORE EXITS.; C. EXTERIOR EGRESS COMPONENTS AT OTHER THAN THE LEVEL OF EXIT DISCHARGE UNTIL EXIT DISCHARGE IS ACCOMPLISHED FOR BUILDINGS
- REQUIRED TO HAVE TWO OR MORE EXITS. D. INTERIOR EXIT DISCHARGE ELEMENTS, AS PERMITTED IN SECTION 1027.1, IN

DOORWAYS IN BUILDINGS REQUIRED TO HAVE TWO OR MORE EXITS.

- BUILDINGS REQUIRED TO HAVE TWO OR MORE EXITS. E. EXTERIOR LANDINGS, AS REQUIRED BY SECTION 1008.1.5, FOR EXIT DISCHARGE
- 13. THE EMERGENCY POWER SYSTEM SHALL PROVIDE POWER FOR A DURATION OF NOT LESS THAN 90 MINUTES AND SHALL CONSIST OF STORAGE BATTERIES, UNIT EQUIPMENT OR AN ON-SITE GENERATOR. THE INSTALLATION OF THE EMERGENCY POWER SYSTEM SHALL BE IN ACCORDANCE WITH SECTION 2702.
- 14. EMERGENCY LIGHTING FACILITIES SHALL BE ARRANGED TO PROVIDE INITIAL ILLUMINATION THAT IS AT LEAST AN AVERAGE OF 1 FOOT-CANDLE (11 LUX) AND A MINIMUM AT ANY POINT OF 0.1 FOOT CANDLE (1 LUX) MEASURE ALONG THE PATH OF EGRESS AT FLOOR LEVEL. ILLUMINATION LEVELS SHALL BE PERMITTED TO DECLINE TO 0.6 FOOT-CAN (6 LUX) AVERAGE AND A MINIMUM AT ANY POINT OF 0.06 FOOT-CANDLE (0.6 LUX) AT THE END OF THE EMERGENCY LIGHTING TIME DURATION. A MAXIMUM-TO-MINIMUM ILLUMINATION UNIFORMITY RATION OF 40 TO 1 SHALL NOT BE

FIRE DEPARTMENT NOTES

AREA IF EQUIPPED WITH A COMMERCIAL HOOD SYSTEM.

- 1. "K" RATED PORTABLE FIRE EXTINGUISHER(S) SHALL BE PROVIDED FOR THE KITCHEN
- 2. MINIMUM 2A 10B:C FIRE EXTINGUISHERS SHALL BE PROVIDED. TRAVEL DISTANCE TO ANY EXTINGUISHER SHALL NOT EXCEED 75 FEET FROM ANY PORTION OF THE BUILDING. EXTINGUISHER(S) SHALL BE HUNG NO HIGHER THAN 44 INCHES MEASURED FROM THE FLOOR TO THE TOP OF THE EXTINGUISHER.
- 3. PLANS FOR ANY AUTOMATIC SPRINKLER SYSTEM (INCLUDING TENANT IMPROVEMENT WORK), HOOD SUPPRESSION SYSTEM AND/OR ALARM SYSTEM, SHALL BE SUBMITTED WITH FEES TO JURISDICTION FIRE DEPARTMENT FOR REVIEW AND
- APPROVAL PRIOR TO INSTALLATION. 4. PANIC HARDWARE: EACH DOOR IN A MEANS OF EGRESS FROM A GROUP A, OR ASSEMBLY AREA NOT CLASSIFIED AS AN ASSEMBLY OCCUPANCY, E. I-2 OR I-2.1 OCCUPANCIES HAVING AN OCCUPANT LOAD OF 50 OR MORE AND ANY GROUP H OCCUPANCY SHALL NOT BE PROVIDED WITH A LATCH OR LOCK UNLESS IT IS PANIC
- 5. LOCKS AND LATCHES, SECTION 1008.1.9.3 ITEM 2: IN BUILDINGS IN OCCUPANCY GROUP A HAVING AN OCCUPANT LOAD OF 300 OR LESS, GROUPS B, F, M AND S, AND IN PLACES OF RELIGIOUS WORSHIP, THE MAIN EXTERIOR DOOR OR DOORS ARE PERMITTED TO BE EQUIPPED WITH KEY-OPERATED LOCKING DEVICES FROM THE EGRESS SIDE PROVIDED: A READILY VISIBLE DURABLE SIGN IS POSTED ON THE EGRESS SIDE ON OR ADJACENT TO THE DOOR STATING: "THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED". THE SIGN SHALL BE IN LETTERS 1 INCH HIGH ON A CONTRASTING BACKGROUND.
- NOTE: THE USE OF THE KEY-OPERATED LOCKING DEVICE IS REVOCABLE BY THE BUILDING OFFICIAL FOR DUE CAUSE.
- 6. DECORATIVE MATERIALS: IN EVERY GROUP A, E, I, R-1 AND R-2 OCCUPANCIES ALL DRAPES, HANGINGS, CURTAINS, DROPS AND ALL OTHER DECORATIVE MATERIAL INCLUDING CHRISTMAS TREES, THAT WOULD TEND TO INCREASE THE FIRE AND PANIC HAZARD SHALL BE MADE FROM A NON FLAMMABLE MATERIAL, OR SHALL BE TREATED AND MAINTAINED IN A FLAME-RETARDANT CONDITION BY MEANS OF A FLAME-RETARDANT SOLUTION OR PROCESS APPROVED BY THE "STATE FIRE MARSHAL". PER CALIFORNIA CODE OF REGULATIONS TITLE 19, ARTICLE 3, SUBSECTION 3.08 - DECORATIVE MATERIALS. PROVIDE A CALIFORNIA STATE FIRE MARSHAL CERTIFICATE OF FLAME RETARDANT OR A CALIFORNIA STATE FIRE MARSHAL APPROVED TESTING LAB CERTIFICATION FOR ANY DECORATIVE MATERIALS PRIOR TO FINAL INSPECTIONS. SAMPLES (4" X 12") ARE REQUIRED TO BE SUBMITTED TO VCFD FOR TESTING AND APPROVAL.
- 7. ADDITIONAL EXIT SIGNS AND EMERGENCY LIGHTING MAY BE REQUIRED PRIOR TO FINAL INSPECTION FOR OCCUPANCY. A PRELIMINARY WALK-THROUGH INSPECTION IS
- 8. MAXIMUM OCCUPANT LOAD SIGN(S) SHALL BE POSTED IN ASSEMBLY AREA(S).

ACCESSIBILITY NOTES

- 1. IN BUILDINGS AND FACILITIES, FLOORS OF A GIVEN STORY SHALL BE A COMMEN LEVEL THROUGHOUT, OR SHALL BE CONNECTED BY PEDESTRIAN RAMPS, PASSANGER ELEVATORS, OR SPECIAL ACCESS LIFTS.
- 2. FLOOR SURFACES SHALL BE SLIP RESISTANT

ACCESSIBILITY NOTES

- 3. EVERY CORRIDOR AND AISLE SERVING AN OCCUPANT LOAD OF 10 OR MORE SHALL BE NOT LESS THAN 44" IN WIDTH.
- 4. ABRUPT CHANGES IN LEVEL ALONG ANY ACCESSIBLE ROUTE SHALL NOT EXCEED 1/2" IN HEIGHT. LEVEL CHANGES NOT EXCEEDING 1/4" MAY BE VERTICAL BEVEL OTHERS WITH A SLOPE NO GREATER THAN 1:2.
- 5. LATCHING AND LOCKING DOORS THAT ARE HAND ACTIVATED AND WHICH ARE IN A PATH OF TRAVEL SHALL BE OPERABLE WITH A SINGLE EFFORT BY LEVER TYPE HARDWARE, PANIC BARS, PUSH-PULL ACTIVATING BARS, OR OTHER HARDWARE DESIGNED TO PROVIDE PASSAGE WITHOUT REQUIRING THE ABILITY TO GRASP THE OPENING HARDWARE. MOUNT DOOR OPENING HARDWARE BETWEEN 30" AND 44" ABOVE
- 6. CENTER HAND ACTIVATED DOOR OPENING HARDWARE BETWEEN 30" AND 44" ABOVE FINISHED FLOOR.
- 7. MAXIMUM PULL OR PUSH EFFORT TO OPERATE DOORS SHALL NOT EXCEED 5 LBS. FOR EXTERIOR AND INTERIOR DOORS, MEASURED AT RIGHT ANGLES TO HINGED DOORS AND AT CENTER PLANE OF SLIDING OR FOLDING DOORS. CORRESPONDING DEVICES OR AUTOMATIC DOOR OPERATORS MAY BE UTILIZED TO MEET THE ABOVE STANDARDS. MAXIMUM EFFORT TO OPERATE REQUIRED FIRE DOOR MAY BE INCREASED NOT TO EXCEED 15 LBS.
- 8. BOTTOM 10" OF ALL DOORS (EXCEPT SLIDING AND AUTOMATIC) SHALL HAVE A SMOOTH UNINTERRUPTED SURFACE TO ALLOW THE DOOR TO BE OPENED BY A WHEELCHAIR FOOTREST WITHOUT CREATING A TRAP OR HAZARDOUS CONDITION. PROVIDE 10" HIGH SMOOTH PANEL ON PUSH SIDE OF NARROW FRAME DOORS.
- 9. EVERY REQUIRED ENTRANCE OF PASSAGE DOORWAY SHALL BE NOT LESS THAN 3'-0" IN WIDTH AND NOT LESS THAN 6'-8" IN HEIGHT. DOORS SHALL BE CAPABLE OPENING AT LEAST 90 DEGREES AND SHALL BE SO MOUNTED THAT THE CLEAR WIDTH OF THE DOORWAY IS NOT LESS THAN 32".
- 10. WHERE A PAIR OF DOORS IS UTILIZED, AT LEAST ONE OF THE DOORS SHALL PROVIDE A CLEAR, UNOBSTRUCTED OPENING WIDTH OF 32" WITH THE LEAF POSITIONED AT AN ANGLE OF 90 DEGREES FROM ITS CLOSED POSITION.
- 11. IDENTIFY ACCESSIBLE ENTRANCES WITH AT LEAST ONE STANDARD SIGN AND ADDITIONAL DIRECTIONAL SIGNS, AS REQUIRED, VISIBLE FROM APPROACHING PEDESTRIAN WAYS.
- 12. THE FLOOR OR LANDING ON EACH SIDE OF AN ENTRANCE OR PASSAGE DOOR SHALL BE LEVEL AND CLEAR. THE LEVEL AND CLEAR AREA SHALL HAVE A LENGTH IN THE DIRECTION OF THE DOOR SWING OF AT LEAST 60" AND A LENGTH IN THE OPPOSITE DIRECTION OF 48" AS MEASURED AT RIGHT ANGLES TO THE PLANE OF THE DOOR IN ITS CLOSED POSITION.

13. FLOORS OR LANDING SHALL NOT BE MORE THAN 1/2"

OF THE DOORWAY. CHANGES IN LEVEL BETWEEN 1/4" AND 1/ 2" SHALL BE BEVELED WITH A SLOPE NO GREATER THAN 1:2. 14. TO ALERT THE VISUALLY IMPAIRED, MARK THE UPPER APPROACH AND THE LOWER THREAD OF EACH INTERIOR STAIR WITH A CONTRASTING COLOR STRIP AT LEAST 2"

WIDE, PLACES PARALLEL TO AND NOT MORE THAN 1" FROM THE NOSE OF THE STOP OR

LANDING. THE STRIP SHALL BE OF A MATERIAL THAT IS AT LEAST AS SLIP RESTAURANT

LOWER THAN THE THRESHOLD

- AS THE THREADS OF THE STAIR. 15. CENTER ELECTRICAL RECEPTACLE OUTLETS NOT LESS THAN 15" ABOVE THE FLOOR
- OR WORKING PLATFORM. 16. SANITARY FACILITIES LOCATED ON AN ACCESSIBLE FLOOR OF A BUILDING SHALL BE ACCESSIBLE TO THE PHYSICALLY DISABLED.
- 17. ENTRY TO SANITARY FACILITIES SHALL BE: A. 44" CLEAR OR CORRIDORS WHERE OCCUPANT LOAD IS 10 OR MORE. 3. DOORWAYS TO HAVE 32" CLEAR OPENING C. ON APPROACH SIDE, PROVIDE 60" CLEAR LEVEL SPACE WHEN DOOR SWINGS

TOWARD APPROACH, AND 48" CLEAR SPACE WHEN DOOR SWINGS AWAY FROM

- 18. TOILET ROOM ACCESSORIES: A. MOUNT BOTTOM EDGE OF MIRRORS NO HIGHER THAN 40" ABOVE FINISHED
- B. MOUNT TOILET TISSUE DISPENSERS WITHIN 7" MIN AND 9" MAX FROM THE FRONT OF THE TOILET SEAT. C. MOUNT DISPENSING AND DISPOSAL FIXTURES (TOWEL, SANITARY NAPKINS, WASTE, ETC.) WITH OPERATING PARTS NO HIGHER THAN 40" FROM THE FLOOR.
- 19. SINGLE ACCOMMODATION TOILET FACILITIES: A. WATER CLOSET SHALL BE 28" CLEAR FROM FIXTURES AND 32" FROM WALLS. B. MINIMUM CLEAR SPACE IN FRONT OF A WATER CLOSET SHALL BE 48"

ACCESSIBLE TO THE DISABLED.

20. WATER CLOSET HEIGHT (AT TOP OF SEAT) SHALL BE BETWEEN 17" AND 19" ABOVE FINISHED FLOOR.

C. A 36" X 48" SPACE IS PERMITTED IN FRONT OF EXISTING WATER CLOSETS

- 21. MOUNT FLUSH VALVE CONTROL NO MORE THAN 44" ABOVE FINISHED FLOOR, ON SIDE OF TOILET WITH THE GREATEST SEPARATION FROM ADJACENT WALL OR OTHER
- 22. PROVIDE GRAB BARS ON EACH SIDE, OR ON ONE SIDE AND BACK OF WATER CLOSET:
- A. GRAB BARS TO BE A.F.F. AND PARALLEL TO FLOOR B. SIDE BARS TO BE 42" LONG AND PROJECT 24" IN FRONT OF WATER CLOSET STOOL. GRAB BAR AT BACK TO BE 36" LONG.
- C. DIAMETER OF GRAB BARS TO BE BETWEEN 1-1/4" AND 1-1/2". D. PROVIDE 1-1/2" CLEAR BETWEEN GRAB BARS AND WALL. E. GRAB BARS (INCLUDING CONNECTORS, FASTENERS, SUPPORT BACKING, ETC.) SHALL SUPPORT A 250 LB. LOAD.
- G. GRAB BARS AND ANY ADJACENT SURFACE SHALL BE FREE OF SHARP OR ABRASIVE ELEMENTS.

F. GRAB BARS SHALL NOT ROTATE WITHIN THEIR FITTINGS.

- H. EDGES SHALL HAVE A MINIMUM RADIUS OF 1/8" 23. PROVIDE A 30" X 48" CLEAR FLOOR SPACE IN FRONT OF LAVATORY TO PERMIT FORWARD APPROACH.
- PROVIDE KNEE CLEARANCE UNDER FRONT LIP EXTENDING 30" MINIMUM WIDTH, 8" MINIMUM DEPTH AT TOP, AND 17" MINIMUM AT BOTTOM AND 9" ABOVE FINISHED FLOOR. 25. FAUCET CONTROLS AND OPERATING MECHANISMS SHALL BE OPERABLE WITH ONE HAND AND SHALL NOT REQUIRE TIGHT GRASPING, PINCHING, OR TWISTING OF THE WRIST. THE FORCE REQUIRED TO ACTIVATE CONTROLS SHALL BE NO GREATER THAN 5

24. MOUNT LAVATORIES 29" MINIMUM CLEAR FROM FLOOR TO BOTTOM OF APRON.

REMAINS OPEN FOR AT LEAST 10 SECONDS. 26. INSULATE OR OTHERWISE COVER HOT WATER AND DRAIN PIPES UNDER LAVATORIES.

LBS. LEVER OPERATED, PUSH TYPE AND ELECTRONICALLY CONTROLLED MECHANISMS

ARE EXAMPLES OF ACCEPTABLE DESIGNS. SELF CLOSING ARE ALLOWED IF FAUCET

27. NO SHARP OR ABRASIVE SURFACES UNDER LAVATORIES



US Office: 24001 Calle De La Magdalena, unit 3896 Laguna Hills, CA 92653
Tel: (415) 316 7162 info@pixelarchltd.com

Revision Notes: Description

COPYRIGHT THIS DRAWING IS AN INSTRUMENT OF SERVICE AND AS SUCH. REMAINS THE PROPERTY OF PIXELARCH LTD. PERMISSION FOR USE OR REPRODUCTION IS LIMITED AND CAN BE EXTENDED ONLY BY WRITTEN PERMISSION WITH OWNER, PIXELARCH LTD.

GENERAL NOTES

JAN. 19, 2023

Drawing Title:

SPECIFICATIONS

DIVISION 00 - CONDITIONS OF CONTRACT 0.01 Terminology

Referenced Organizations

- a. ACI American Concrete Institute (www.concrete.org) AISC American Institute of Steel Construction (www.aisc.org)
- AITC American Institute of Timber Constructio (www.aitc-glulam.org)
- ANSI American National Standard Institute (www.ansi.org)
- APA American Plywood Association (www.apawood.org) ASHRAE American Society of Heating, Refrigeration, and Air Conditioning Engineering (www.ashrae.org)
- ASTM American Society for Testing and Materials (www.astm.org)
- AWI Architectural Woodwork Institute (www.awinet.org) AWS American Welding Society (www.aws.org)
- AAMA Architectural Aluminum Manufacturers' Association (www.aamanet.org)
- CRI Carpet and Rug institute (www.carpet-rug.org)
- CEC California Energy Commission (www.energy.ca.gov)
- CRSI Concrete Reinforcing Steel Institute (www.crsi.org)
- n. FS Federal Specification (http://apps.fss.gsa.gov/pub/fedspecs/)
- GA Gypsum Association (www.gypsum.org)
- GANA Glass association of North America (www.glasswebsite.com) ICC International Code Council (www.iccsafe.org)
- NIST PS National Institute of Standards and Technology, Product Standards (www.nist.org) NEMA National Electrical Manufacturers Association (www.nema.org)
- NFPA National Fire Protection Association (www.nfpa.org)
- NFRC National Fenestration Rating Council (www.nfrc.org)
- NOFMA National Oak Flooring Manufacturers Association (www.nofma.org) w. NPCA National Paint and Coatings Association (www.npca.org)
- x. NRCA National Roofing Contractors Association (www.nrca.net)
- WDMA National Wood Window and Door Association (www.wdma.com) PDCA Painting and Decorating Contractors of America (www.pdca.org)
- aa. SDI Steel Door Institute (www.steeldoor.org)
- ab. SMACNA Sheet Metal and Air Conditioning Contractors National Association (www.smacna.org) ac. TCNA Tile Council of North America (www.tcna.org)
- ad. TPI Truss Plate Institute (www.tpinst.org)
- ae. TRI Tile Roofing Institute (www.tileroofing.org)
- af. UL Underwriters' Laboratories Inc. (www.ui.com) ag. WCLIB West Coast Lumber Inspection Bureau (www.wclib.org)
- ah. WI Woodwork Institute (www.woodworkinstitute.com)
- ai. WWPA Western Wood Products Association (www.wwpa.org) Definitions
- 1. Contract Documents: The Contract Documents shall include the drawings, specifications, structural calculations, soils report, and California Energy Code compliance forms. These documents are intended to supplement and complement each other. In case of conflict, contact the Architect.
- Owner: The term "Owner" shall mean the Owner or the Owner's authorized representative(s). Contractor: The term "Contractor" shall mean the general contractor or the general contractor's authorized representative(s)
- Architect: The term "Architect" shall mean PixelArch ltd. authorized representative(s).
- Engineer: The term "Engineer" shall mean the structural engineer or the structural engineer's authorized representative(s)
- 6. Builder: The term "Builder" shall mean a person or entity who is both an Owner and Contractor, and whose responsibilities are for both Owner and Contractor.

DIVISION 01 - GENERAL REQUIREMENTS

- 1.01 Scope of Work: Contractor shall provide all labor, materials, equipment, permits, and services necessary for construction of the building and site improvements conforming to the contract documents. Drawings and specifications represent finished structure
- The contractor shall be responsible for means and methods of construction including shoring and temporary bracing and shall take all necessary measures to insure the safety of all persons and structures
- Care shall be taken to protect from any damage all trees and vegetation on the site and on adjoining properties. Any trimming or other alteration done to trees shall be done so only by approval of the Owner. The Architect will not be providing the Owner with regular on site contract administration and is available only at request of the Owner. The Contractor is solely responsible for the quality control and construction standards for this project.
- These plans are for general construction purposes only. They are not exhaustively detailed nor fully specified. The drawings were prepared to a level of completion satisfactory for building permit purposes and for construction by a knowledgeable and experienced contractor. The Contractor is responsible for preparation of any supplemental details, product specifications, coordination and installation of all materials and equipment.
- Mechanical, electrical, and plumbing systems are shown for intent only. These systems shall be design/build by the Contractor. The Contractor shall be responsible for all necessary permits, drawings, calculations, and California Energy Code.
- These drawings and specifications are divided into sections for convenience only. Contractors, subcontractors and materials suppliers shall refer to all relevant sections in bidding and performing their work and shall be responsible for all aspects of the work regardless of where the information occurs in the
- Clean-Up: The Contractor will remove all debris from the building site and in general keep the work as clear of rubbish as possible during the course of the work. Before filing the Notice of Completion, the building will be fully cleaned, including all glass polished, floors scrubbed and cleaned, and the building shall be suitable for immediate occupancy by Owner. 1.02 Quality Control
- All work shall comply with applicable requirements of all governing codes, regulations and ordinances. These shall include the latest adopted editions of: The California Building Code (CBC), California Residential Code (CRC), California Electric Code (CEC), California Plumbing Codes (CPC), California Mechanical Code (CMC), California Energy Code (CENC), California Green Building Standards Code (CAL Green), OSHA regulations, and all other health and safety codes, ordinances and requirements adopted by governing agencies. In the case of conflicts between these regulations and the contract documents, the most restrictive shall apply.
- The Contractor shall verify, at the site, all conditions affecting work and shall review the contract documents for any areas of question affecting cost, construction and warranty and any drawing dimensional or note conflict, discrepancy, illegibility or omission. All areas of question shall be brought to the attention of the Architect in writing before commencing any work and/or submitting any bid.
- Commencement of any work shall constitute acceptance by the Contractor of all conditions affecting work. Workmanship throughout shall be of the highest quality of each trade involved.
- The Contractor, before commencing work, shall notify the Owner in writing of any work that cannot be fully guaranteed or executed within the intent of the drawings prior to the bid submittal. All construction shall be in strict conformance with manufacturers' latest written specifications. All discrepancies between these specifications and the contract documents prepared by the Architect and his
- consultants shall be brought to the attention of the Architect before commencing work. Reference to product manufacturer or trade names are for minimum performance standards only. Submittal equals may be allowed upon approval by the Architect. Material and detail substitutions made by the Contractor without written approval by the Architect shall void any responsibility or liability of the Architect as to performance, repair cost, ancillary damage or the performance of related materials and
- Cutting and patching includes cutting into existing construction to provide for the installation or performance of other work and subsequent fitting and patching required to restore surfaces to their original condition. Use materials for cutting and patching that are identical to existing materials.
- Do not cut and patch structural work in a manner that would result in a reduction of load carrying capacity or load-deflection ratio. Submit proposal and obtain Architect's and Engineer's approval before proceeding with cut and patch of structural work.
- Quality control services include inspections and tests performed by independent agencies and governing authorities, as well as by the Contractor. Inspection and testing services are intended to determine compliance of the work and the requirements specified. Approval by a building official does not mean approval or failure to comply with the contract documents. Inspections and testing shall be performed at the request of the Owner, the Architect and/or governing agencies and as set forth in these documents. Quality control services are the Contractor's responsibility, including those specified to be performed by an independent agency and not by the contractor. The Contractor shall employ and pay any independent agency, testing laboratory or other qualified firm to perform quality control services specified. Where results of inspections or tests do not indicate compliance with the contract documents, the Contractor shall be responsible for any repair, replacement, correction and re- test that is required.
- All dimensions shall take precedence over scale shown on the plans, sections, and details. Dimensions are to face of studs, face of foundation, face of concrete block, top of sheathing, top of slab, or center of openings, U.O.N. Do not scale drawings. Contractor shall verify all dimensions and review any conflicts or discrepancies with the Architect prior to commencement of work.

DIVISION 02 - SITEWORK

- 2.01 Soils Report: All work shall be in conformance with the Soils, Compaction and Geological Report.
- The Contractor shall have the Soils Engineer review and approve in writing to the Building Official and Architect that the foundation and site design are in conformance with the Soils Report prior to commencement of work.
- The Contractor shall be solely responsible for compliance with all recommendations of the Soils Report. Prior to the contractor requesting a foundation inspection by the building department, the Soils Engineer shall advise the Building Official and Architect in writing that: a. Site grading, subgrade preparation, cutting slopes, excavation, placement of engineered fill material
- and compaction is in accordance with the Soils Report. The utility trenches have been properly backfilled and compacted.
- c. The foundation excavations, forming, footing and pier depths, and reinforcement comply with the soils report and approved plans.

2.02 General Requirements

- The site plan is not a survey. It is based on site information provided by the Owner and is for building and site work layout only. The Contractor shall verify on site all grades, soil conditions, ground water, existing improvements, property lines, easements, setbacks, utilities and substructures. Where discrepancies with
- the drawings occur, contact Architect. Grade surface of fill under concrete slabs shall be smooth and even, free of voids, compacted as specified
- and to required elevation At raised foundations, pad grade under building shall have positive slope to a perforated drain set in gravel trench. Extend pipe to all portions of underfloor area. The drain shall discharge into the street or approved
- drainage facility. Unless otherwise detailed or noted, a perforated drain set in a gravel trench shall be installed around the entire perimeter of the foundation. The drain shall discharge into the street or approved drainage facility.
- Use only rigid pipe, flexible pipe will not be allowed. It shall be the responsibility of the Contractor to take proper erosion control measures. The Contractor
- shall be responsible for proper surface and subsurface drainage of the site. Slope all finish grading away from buildings, walks, drives or decks and provide catch basins where required. Finish grades shall be held down in planting areas. The Contractor shall provide and install a 6" minimum
- thickness of clean select top soils in these areas. Rough grading for slabs-on-grade shall be within 2/10th of one foot, plus or minus.
- Site grading shall be within 5/10th of one foot, plus or minus.
- All roof drainage shall be piped in a closed pipe system to street or approved drainage facility (U.O.N.). Builder shall provide landscape development guidelines to Owner that shall include information on site maintenance and development and state such items as "Irrigation system shall be designed to prevent saturation of soil adjacent to building".
- All utilities unless indicated otherwise shall be installed under ground. The Contractor shall be responsible to insure that all trenching within building area shall be backfilled and compacted with structural soils material free of any rocks or other sharp objects which may damage underground utilities.
- Underground piping shall be laid to a minimum 24" depth below finished grade. When utilities are placed in a common trench, all utilities shall maintain separations and coverage both vertically and horizontally, as required by applicable codes.

DIVISION 03 - CONCRETE

- 3.01 Quality Control In addition to complying with all pertinent codes and regulations, comply with all applicable provisions of the latest editions of:
- a. ACI 301 "Specifications for Structural Concrete for Buildings"
- b. ACI 318 "Building Code Requirements for Reinforced Concrete"
- c. CRSI "Manual of Standard Practice" d. See Structural Engineer's drawings for additional requirements.
- 3.02 General Requirements Provide underfloor vents as per CBC 1203.3 or CRC R408.1. Add two 6 x 14 vents to garage. All first
- floor double framed areas shall be vented. Provide expansion and control joints in all exterior concrete slabs. Spacing of joints shall be per industry
- standard (U.O.N.). Verify joint layout with Architect. Refer to architectural, structural, mechanical, plumbing and electrical drawings for all moulds, grooves and ornamental clips, location of sleeves, inserts, etc. to be cast in concrete and for extent of depressions,
- Finishes: a. All interior slabs shall receive trowel smooth finish (U.O.N.).
- All driveways, sidewalks, and stairs shall receive broom-smooth finish (U.O.N). Garage slabs and other interior slabs that will remain unfinished shall be treated with Lipidolith

Hardner by Sonneborn, or equal.

curbs and ramps.

DIVISION 04 - MASONRY 4.01 Quality Control

- Glass Block: Minimum performance specifications shall be as Pittsburgh Corning glass block units. The units shall be the pattern and size indicated on the plans.
- Precast architectural concrete columns and trims: Concrete Designs Inc. (CDI) U.O.N.
- Grout for precast concrete: ASTM A 118.6, Latex Portland Cement, color to match precast concrete. Epoxy Grout: ANSI A 108.6 and A118.3. 4.02
- 4.02 General Requirements Concrete Block
- a. Mortar joints to be "flush" (U.O.N.).
- b. Bond shall be "running" (U.O.N.). Brick:
- a. Mortar joints shall be "raked" (U.O.N.). Raked joints shall be not more than 3/8" deep, and where exposed to weather, shall be tooled. Brick joints shall be concaved where subject to b. Bond shall be "running" (U.O.N.).
- Stone:
- a. Field Sample: A sample panel shall be built approximately 4 feet by 6 feet. This sample panel may be a part of the project. Veneer installation shall not proceed until the sample panel is accepted by the Architect and Owner. Full size units which have been selected and approved by the Architect and the Owner to show color range, maximum texture range, bond, mortar, tooling of joints, and quality of workmanship shall be used in the sample panel. The remainder of the veneer installation shall be consistent with the approved sample panel. Glass Block:
- a. Mortar for glass block installed on exterior walls and other damp location shall be waterproofed with Laticrete 8510 or equal.

DIVISION 05 - METALS 5.01 General Requirements

- All bolt heads and nuts that bear on wood shall have malleable iron washers if exposed or cut
- washers if concealed.
- Exposed welds shall be ground smooth. Shop paint structural steel work, except those members or portions of members to be embedded in concrete or mortar. Paint the initial 2" of embedded areas only. Do not paint surfaces which are to be welded or high strength bolted with friction type connections. After installation is completed, all welded and other abraded areas shall be touched up. On surfaces inaccessible after assembly or
- erection, apply two (2) coats of the specified primer. All exterior steel, exposed, concealed or embedded, or where called for on the Drawings, shall be thoroughly zinc-coat galvanized after fabrication by the hot-dipped method. Touch- up field welds with similar galvanizing product.
- Dissimilar Materials in contact with each other shall be protected to prevent galvanic or corrosive action. Use vinyl pressure tape, polyisobutylene tape, or similar product.
- All metals in contact with pressure treated wood shall be hot dipped galvanized, see Simpson Strong-Tie for recommended finishes for their connectors. Also see structural engineering specifications for further information.

DIVISION 06 - WOOD AND PLASTICS

- 6.01 Quality Control:
- Materials shall meet or exceed the following standards:
- a. Lumber: A. Structural lumber and their wood fasteners shall conform with CBC Chapter 23 and/or relevant chapters of the CRC.
- B. All wood in contact with concrete or masonry or located within 8" of finish grade shall be
- pressure treated Douglas or Hem Fir with an approved preservative. C. All timbers 6 x 8 and larger exposed to view shall be free of heart center (FOHC), with moisture
- content of 22% maximum. D. Max. deflection (DL + LL) shall be: Floor with Tile = L/ 720 All wood shall be nontropical, reused, reclaimed, or FSC Certified

- 6.02 General Framing Requirements:
- a. Block floor joists at all supports, line up double joists under all walls parallel to floor joists and space
- double joists under plumbing walls. b. Provide solid full width blocking or post below all structural posts - continuous to foundation.
- c. Provide blocking and nailers for all finishes and fixtures as required.
- d. Provide blocking in walls at ceiling lines
- e. Corbles, knee braces, etc., shall be construction select materials. At double framed floors "sleepers" shall be perpendicular to framing below. 6.03 Attic Ventilation Requirements
- Provide attic and soffit ventilation as per CBC 11203.2 or CRC R806. Vent all double framed areas. See Roof Plan for calculations. 6.04 Finish Carpentry:
- All millwork and case work shall be in accordance with AWI/AWMAC "Architectural Wood Standards" custom or premium grade standards, latest edition. All cabinets and millwork shall be selected by the owner.
- Provide 30" clear above kitchen range to unprotected underside of upper cabinetry or 24" clear to metal hood as per CMC Section 916.1 & 916.2. Plastic laminates and solid surfacing products shall meet or exceed ANSI/NEMA standards LD.
- finishes. Install level and plumb. Comply with manufacturer's instructions for support of supplied units. Install all trim in as long of lengths as possible. All splices in finish members shall be bevel splices. Where joints within a piece are required they shall be as unapparent as possible.

Install and anchor all cabinetry to preclude movement, overturning, or distortion to other materials or

DIVISION 07 - THERMAL AND MOISTURE PROTECTION

- 7.01 Quality Control Materials shall meet or exceed the following standards:
- a. Insulation shall be installed per the California Energy Code requirements.
- b. Thermal Batt/Blanket Insulation: Mineral-Fiber Blanket complying with ASTM C 665, Type I (blankets without membrane facing).
- c. Thermal insulation/blown-in blanket insulation glass fiber loose-fill complying with ASTM C 764 Type I (for pneumatic) or Type II (for poured) in attic. d. Sound Insulation: Unfaced mineral fiber blanket/batt insulation complying with ASTM C 665, Type I,

minimum thickness equal to stud depth to entirely fill the void space, nominal 0.70 to 2.50 -pcf

- e. All plumbing walls adjacent to interior living spaces shall be sound insulated with fiberglass batts. Concrete Tile Roofing:
- a. All work shall comply with the TRI "Concrete and Clay Tile Installation Manual for Moderate Climate Regions and CBC 1507.3 or CRC 905.3
- b. Concrete Tile Roofing shall be applied according to manufacturers specifications. c. The minimum performance standards for concrete tile roofing shall be Eagle Roofing Products (ICC ESR-1900) or equal as approved by Owner and bear a UL Class A fire proof rating. Installed weight shall be a maximum of 900 lbs. per square.
- d. Trim units shall include manufacturer's standard ridge, hip and rake pieces. Color as selected by Owner (U.O.N.). Minimum one nail per tile, two nailes on all rake tile. Minimum pitch shall be as per manufacturer's specifications. Underlayment for concrete or clay tile roofing shall be one layer of 30 lb. asphalt-saturated organic roofing felt, complying with ASTM D 226, 36" wide applied per manufacturer's recommendations. 3-ply built up roof underlayment required for pitch less than 3:12.
- e. Roofing nails shall be aluminum or hot dip galvanized 11 or 12 GA sharp, pointed conventional roofing nails with barbed shanks, min. 3/8" dia. head and or sufficient length to penetrate min. 3/4" into solid decking or to penetrate through plywood sheathing (U.O.N.). The roofing contractor shall supply to the Owner a written guarantee to repair without cost to the Owner, any leaks due to faulty materials or workmanship, which develop within 1 year from the date
- of acceptance by Owner of completed building. During this time period, any repair work required because of Act of God, abuse, alterations, or failure to the substrate and/or supporting structure (other than that caused by defects in the roofing work) shall be completed by the contractor and paid for by the Owner, promptly after compeltion of the required repair work in each instance. The roofing contractor shall furnish the manufacturer's standard limited material warranty for a minimum of 10 years from the date of completion of the roof.
- Asphalt Shingle Roofing: a. All work shall comply with the NCRA "Roofing and Waterproofing Manual" and CBC 1507.2 or CRC
- b. Asphalt shingles shall be applied according to manufacturers specifications.
- c. The minimum performance standard for asphalt shingles shall be Elk Premium Roofing Prestique Two or equal as approved by Owner and bear a UL Class A fire proof rating. Trim units shall include manufacturer's standard ridge and hip pieces. Color as selected by Owner (U.O.N.). Minimum pitch
- as per manufacturer's recommendations. For asphalt shingle underlayment shall be 15 lb, felt, 2 layers at pitch less than 4:12. e. Roofing nails shall be aluminum or hot dip galvanized 11 or 12 GA sharp, pointed conventional roofing nails with barbed shanks, min. 3/8" dia. head and or sufficient length to penetrate min. 3/4"
- into solid decking or to penetrate through plywood sheathing (U.O.N.). f. The roofing contractor shall supply to the Owner a written guarantee to repair without cost to the Owner, any leaks due to faulty materials or workmanship, which develop within 1 year from the date of acceptance by Owner of completed building. During this time period, any repair work required because of Act of God, abuse, alterations, or failure to the substrate and/or supporting structure (other than that caused by defects in the roofing work) shall be completed by the contractor and paid for by the Owner, promptly after compeltion of the required repair work in each instance. The roofing contractor shall furnish the manufacturer's standard limited material warranty for a minimum of 10
- years from the date of completion of the roof. Built-up Roofing:
- a. All work shall comply with the NCRA "Roofing and Waterproofing Manual" and CBC 1507.10 or CRC
- Built-up roofing shall be applied according to manufacturers specifications. c. The minimum performance standard for built up roofing for nailable decks shall be Johns Manville 4GNC or equal as approved by Owner and bear a Class A fire proof rating. All products and components shall be by same manufacture. Color as selected by Owner (U.O.N.). d. The roofing contractor shall supply to the Owner a written guarantee to repair without cost to the
- Owner, any leaks due to faulty materials or workmanship, which develop within 1 year from the date of acceptance by Owner of completed building. During this time period, any repair work required because of Act of God, abuse, alterations, or failure to the substrate and/or supporting structure (other than that caused by defects in the roofing work) shall be completed by the contractor and paid for by the Owner, promptly after compeltion of the required repair work in each instance. The roofing contractor shall furnish the manufacturer's standard limited material warranty for a minimum of 10 years from the date of completion of the roof.

Metal roof panels:

Deck requirements. Metal roof panel roof panels shall applied to a solid or closely fitted deck. Except where the roof

Deck slope.

covering is specially designed to be applied to spaced supports.

- Minimum slopes for metal roof panels shall comply with following: 1. The minimum slope for lapped, no soldered seam metal roof panels without applied lap sealant shall be three units vertical in 12 units horizontal (25-percent slope). 2. The minimum slope for lapped. No-soldered seam metal roof panels with applied lap sealant shall
- be one-half unit vertical in 12 units horizontal (4-percent slope). Lap sealants shall be applied in accordance with the approved manufacturer's installation instructions. 3. The minimum slope for standing-seam metal roof panel systems shall be one-quarter unit vertical in

12 units horizontal (2-percent slope).

Material standards. Metal-sheet roof covering systems that incorporate supporting structural members shall be designed in accordance with chapter 22. Metal-sheet roof coverings installed over structural decking shall comply with Table 1507.4.3(1). The materials used for metal -sheet roof coverings shall be naturally corrosion resistant or provided with corrosion resistance in accordance with the standards and minimum thicknesses shown in Table 1507.4.3(2).

TABLE 1507.4.3(1) METAL ROOF COVERINGS

ROOF COVERING TYPE	STANDARD APPLICATION RATE/THICKNESS
Aluminum	ASTM B209. 0.024 inch minimum thickness for roll-formed panels and 0.019 inch minimum thickness for press-formed shingles
Aluminum-zinc Alloy coated steel	ASTM A792 AZ 50
Cold-rolled copper	ASTM B370 minimum 16 oz./sq ft and 12 oz./sq ft high yield copper for metal-sheet roof covering systems. 12 oz./sq ft for preformed metal shingle systems.
Copper	16 oz./sq ft for metal-sheet roof-covering systems, 12 oz./sq ft for preformed metal shingle system
Galvanized steel	ASTM A653 G-90 zinc-coated
Hard lead	2 lbs./sq ft
Lead-coated copper	ASTM B101
Prepainted steel	ASTM A755
Soft lead	3 lbs./sq ft
Stainless steel	ASTM A240. 300 Series Alloys
Steel	ASTM A924
Teme and teme-coated stainless	Teme coating of 40 lbs. per double base box. Field painted where applicable in accordance with manufacturer's installation instructions.
Zinc	.0277 inch minimum thickness. 99.995% electrolytic high grade zinc with alloy additives of copper (0.08%-0.20%). Titanium (0.07%-0.12%) and aluminum (0.015%).

TABLE 1507.4.3(2) MINIMUM CORROSION RESISTANCE

()	
55% Aluminum-zinc alloy coated steel	ASTM A792 AZ 50
5%Aluminum alloy-coated steel	ASTM A875 GF60 50
Aluminum-coated steel	ASTM A463 T2 65
Galvanized steel	ASTM A653 G-90
Prepainted steel	ASTM 755

Metal roof panels shall be secured to the supports in accordance with the approved manufacturer's fasteners. In the absence of manufacturer recommendations, the following fasteners shall be used:

- 1. Galvanized fasteners shall be used for steel roofs. 2. Copper, brass, bronze, copper alloy or 300 series stainless-steel fasteners shall be used for copper roofs.
- 3. Stainless-steel fasteners are acceptable for all types of metal roofs.

4. Aluminum fasteners are acceptable for aluminum roofs attached to aluminum supports.

Underlayment and high wind: Underlayment applies in areas subject to high winds [V... greater than 110mph (49 m/s) as determined in accordance with section 1609.3.1] shall be applied with corrosion-resistant fasteners in accordance with

the manufacture's installation instructions. Fasteners are to be applied along the overlap not more than 36" (914 mm) on center. Underlayment installed where Vasa in accordance with section 1609.3.1, equals or exceeds 120 mph (54 m/s) shall comply with ASTM D226 type II, ASTM D4869 type IV, or ASTM D1970. The underlayment shall be attached in grid pattern of 12 inches (305 mm) between side laps with a 6 inch (152 mm) spacing at the side laps. Underlayment shall be applied in accordance with the manufacturer's installation instructions except all laps shall be a minimum of 4 inches (102 mm). Underlayment shall be attached using metal or plastic cap nails with a head diameter of not less than 1 inch (25 mm) with a thickness of at least 32-gage [0.0134 inch (0.34 mm)] sheet metal. The cap nail shank shall be a minimum of 12 gage [0.105 inch (2.67 mm)] with a length to penetrate through the roof sheathing or minimum of 3/4" (19.1 mm)

into the roof sheathing. **Exception:** As an alternative, underlayment complying with ASTM D 1970 shall be permitted.

The roofing contractor shall supply to the Owner a written guarantee to repair without cost to the Owner, any leaks due to faulty materials or workmanship, which develop within 1 year from the date of acceptance by Owner of completed building. During this time period, any repair work required because of Act of God, abuse, alterations, or failure to the substrate and/or supporting structure (other than that caused by defects in the roofing work) shall be completed by the contractor and paid for by the Owner, promptly after compeltion of the required repair work in each instance. The roofing contractor shall furnish the manufacturer's standard limited material warranty for a minimum of 10

years from the date of completion of the roof.

- a. All work shall comply with the SMACNA "Architectural Sheet Metal Manual". b. All metal flashing to conform to ASTM A 653, commercial grade (zinc coated G 90). c. All metal flashing shall be 26 gauge for work less than 8" wide, 20 gauge for work over 8" wide or as
- indicated on the drawings. Use 20 gauge minimum for clips. d. Sheet metal flashing shall be installed at all locations where different material intersect such as roof to wall, roof to roof, deck/balcony/landing to wall, penetrations into walls, chimneys and as detailed. Flash and counterflash as required to make watertight.

e. The center of all flashing for all through vents and all electrical service connections, shall not be less

recommendations for roofing tile. DIVISION 07 - THERMAL AND MOISTURE PROTECTION (CONTINUED)

 Sheathing Paper: a. Provide sheathing paper under exterior metal lath and plaster, under wood siding, under masonry veneer, under metal flashings and where indicated or detailed.

than 16" from center of any valley. See manufacturer's printed installation instructions

- b. Use Tyvek House Wrap. c. Lapping: Horizontal Joints: Lap paper as detailed and not less than 3 inches; Wall Corners: Wrap paper to overlap not less than 18 inches each side of corner; Vertical Joints: Lap paper not less than
- d. Lap paper over head flashings and base screeds, roof and waterproof membranes, and under sill flashings. Treat penetrations and other details as necessary for adequate weather protection. e. Wall openings: Individually flash all exterior openings for fixtures such as windows, doors and vents

as detailed to make them water tight. Flexible Flashings:

Deck Waterproofing:

d. Moiststop sealant for sealing around windows.

- a. Fortifiber system Moiststop E-Z seal adhesive flashing for dampproofing at all exterior door window heads and jambs. c. Fortiflash 40 mil waterproof flashing for waterproofing at all horizontal plaster surfaces, horizontal penetrations, and windowsills.
- a. The minimum performance standard for waterproof sheet membrane at waterproof decks with tile or concrete finish shall be WR Grace "Bituthene 3000". All products and components shall be by same manufacturer. Install in strict accordance with manufacturer's written instructions to assure waterproof integrity. The minimum performance standard for traffic coatings at waterproof decks shall be Excel-Coat
- pedestrian membrane system or Excel-Coat Fire System for fire-rated decks by Excellent Coatings Inc.. All products and components shall be by same manufacturer. Install in strict accordance with manufacturer's written instructions to assure waterproof integrity. c. Quality Assurance. Pre-installation conference: A pre-installation conference shall be held prior to commencement of field operations to establish procedures to maintain optimum working conditions and to coordinate this work with related and adjacent work. Agenda for meeting shall include review of special details and flashing. This meeting shall include the representatives of the General Contractor,

Applicator, Manufacturer, and Architect. A trained employee of the manufacturer shall be on site

- periodically during membrane waterproofing work to review installation procedures. d. Water test: Deck membranes shall be water tested and approved immediately before installation of finish materials. Water tests shall be witnessed by the Architect. A water test is conducted by closing any deck drains and erecting temporary dams where required to retain water on the waterproofing material surface, then flooding the surface to a minimum depth of 2". Care must be taken so that the weight of water retained does not exceed the load carrying capacity of the structural deck, and that the height of the water does not exceed the lowest flashing. For well sloped decks, tests should be segmented to avoid deep water near drains. The water tests should be conducted on a warm day (i.e. 65 degrees F. minimum). The water should be allowed to remain on the deck for 24 hours minimum, during and after which the areas beneath the membrane should be inspected for leaks. If leaks are detected, the test should be stopped, repairs made, and the area retested. When the test is successful, the drains should be opened and the temporary dams should be removed. Temporary protections boards should be installed over the tested area, and the area roped off to prevent construction traffic across the surface until drainage composite or permanent protections board has been installed.
- Roof Accessories a. The minimum performance standard for prefabricated acrylic skylights shall be Bristolite "AL-CM- 2" (ICC ER-2469) or equal as approved by Owner. Color as selected by owner. Install as per manufacturer's instructions.

- a. Furnish UL Design No. from the "Fire Resistance Directory Volume II" for each required penetration type and configuration. Indicate which materials will be used in firestopping the penetration.
- b. Firestopping materials shall conform to CBC Section 713 for fire resistance standards and requirements for penetrations in walls and partitions and floors. c. Through-Penetration Firestopping Materials: Hilt Construction Chemicals, Inc., International Protective Coatings Corp., Specified Technologies, Inc., The ReclorSeal Corporation, Tremco, Inc., 3M Fire

Protection Products. Provide mortar, sealants and caulk, putty, wrap strips, pillows, bags, and other

complying with ASTM C 612, Type IA and IB. e. Firestopping at Electrical Boxes and Utility Outlets: Utility penetrations in walls, ceilings, or floors requiring protected openings shall be firestopped and sealed with an approved material securely

d. Mineral Fiber Firestopping Materials: Semirigid mineral fiber insulation, nominal 4-pcf density;

types required for UL Design No. for each penetration to receive firestopping.

installed, capable of maintaining its integrity when subjected to test temperature was specified in ASTM E814. Steel electrical outlet boxes which exceed 16-square inches in area shall be protected by 3M "Moldable Putty Pads", Specified Technologies, Inc. "SpecSeal Series SSP Putty Pads." f. Provide solid continuous firestopping wherever the penetration or addition of a construction element

through or adjacent to a fire-rated floor, wall or partition creates a discontinuity of such a rates

h. Fire Rated Partitions: Fire-rated or smoke-rated partitions shall be firestopped with a firestop sealant

- separation. Application limited in size and configuration to tested systems g. Penetrations: Penetrations include conduit, cable, wire, pipe, duct and other elements which pass through one or both outer surfaces of a fire-rated floor, roof, wall, or partition. Fill penetrations as indicated in applicable UL Design No. Verify that annular space around sprinkler pipes through fire-
- as listed in UL "Fire Resistant Directory." Apply minimum 3/8-inch bead at intersection of finish material and adjacent surface, both sides and along entire perimeter. Identify firestop systems after installation. Identify the firestop system that has been installed and

rated walls and floors is provided as required by NFPA 13.

- include the appropriate UL Design Number. Caulking and Sealants/Locations: a. Sealant Locations: Locations such as ceramic tile, plumbing fixtures, and other where mildew resistant sealant is required. Location where high degree of movement is anticipated. Joints and cracks around windows, thresholds, door frames, wall penetrations, connections and other joints necessary to seal off building from outside air and moisture. Between exterior wall sole plate and slab
- dust, wind, air or water. At interior insulated sound walls. Fire stopping at penetrations of fire rated b. Minimum product standards for sealants shall be as follows:

on grade. All joints necessary to make the building watertight and to prevent the passage of dirt,

Color to match wall surface.

Color: Natural Stone

Color: Clear.

Interior Sound Walls at Sill: Tremco Acoustical Sealant or equal. Wood Sole Plate to Concrete, Window Sills and Door thresholds: Dow Corning 790 Silicone Building

Painted Exterior Windows Frames to Metal Frames or Flashing: Dow Corning 999A Glazing Sealant

Exterior Window and Door Frames and Masonry to Cement Plaster: Sonolastic NP 2, by Sonneborn or

Caulking for Joints in Floor Slabs on Grade: PRC Rubber Caulk 230, two-part self-leveling polyurethane, Shore A hardness 35. Joint Fillers: Closed cell inert polyurethane or polyethylene as recommended by caulking manufacturer. Width or diameter of preformed backing material to be 1-1/4 to 1-1/3 times the width of

the joint to be sealed. Fire stopping at penetrations of fire rated assemblies: 3M Fire Protection Products CP 25WB Caulk (U.O.N.), see details. c. Caulking and sealants shall be installed per manufacturer's written specifications. Consult manufacturer when sealant cannot be applied within recommended temperature ranges. All exposed

caulking shall be free of wrinkles, sags, air pockets, ridges and embedded impurities. After joints are completely filled, they shall be tooled to a slight, neat concave joint. d. Sealants shall be compatible with all materials they are in contact with.

DIVISION 08 - DOORS AND WINDOWS

- 8.01 Quality Control Material shall meet or exceed the following standards:
- Wood Doors: a. Doors shall meet or exceed the standards of the AWI/AWMAC "Architectural Wood Standards",
- Section 9, Custom Grade (U.O.N.). b. Wood doors shall be 1-3/4" thick solid core at exterior doors and where noted at selected interior
- doors. 8' interior doors shall be 1-3/4" thick, 6'-8" interior doors shall be $1\frac{3}{8}$ " thick. Stile & Rail Wood Doors:

a. Masonite International Corporation, molded panel series, or equal. See Window & Door schedule. Final windows and doors style to be selected by owner.

PixelArch Itd. US Office: 24001 Calle De La Magdalena, unit 3896 Laguna Hills, CA 92653
Tel: (415) 316 7162 info@pixelarchltd.com

> DEVELOPMENT
> JTRY CLUB DRIVE CAMERON P
> O COUNTY
> 91-002 SSIS DE COUNTE ORADO (

Revision Notes:

THIS DRAWING IS AN INSTRUMENT OF

SERVICE AND AS SUCH. REMAINS THE

CAN BE EXTENDED ONLY BY WRITTEN

PROPERTY OF PIXELARCH LTD. PERMISSION

FOR USE OR REPRODUCTION IS LIMITED AND

PERMISSION WITH OWNER, PIXELARCH LTD.


COPYRIGHT


Drawing Title:


GENERAL NOTES


JAN. 19, 2023















FIRST FLOOR = 575 sq.ft. SECOND FLOOR = 575 sq.ft.

TOTAL 8 UNITS = 9200 sq.ft.

TOTAL = 1150 sq.ft.


1 BUILDING B 1ST FLOOR PLAN
Scale: 3/16" = 1'-0"



FIRST FLOOR = 575 sq.ft.

TOTAL = 1150 sq.ft.


SECOND FLOOR Unit = 575 sq.ft.



PROPOSED 2ND FLOOR PLAN

Scale: 1/4" = 1'-0"

EMERGENCY ESCAPE / RESCUE OPENING (R310)



SECTION 1026 OF THE 2016 INTERNATIONAL BUILDING CODE /SECTION 310 OF THE 2016 INTERNATIONAL RESIDENTIAL CODE

BASEMENTS IN A DWELLING UNIT AND EVERY SLEEPING ROOM BELOW THE FOURTH STORY (INCLUDES ROOMS WHICH COULD BE USED FOR SLEEPING SUCH AS DENS, SEWING ROOMS, STUDY, ETC.) MUST HAVE A LEAST ONE OPERABLE WINDOW OR DOOR APPROVED FOR EMERGENCY ESCAPE OR RESCUE WHICH SHALL OPEN DIRECTLY INTO A PUBLIC STREET, PUBLIC ALLEY, YARD, OR EXIT COURT. THE UNITS MUST BE OPERABLE FROM THE INSIDE TO PROVIDE A FULL CLEAR OPENING WITHOUT THE USE OF SEPARATE TOOLS.

FOR FULL EGRESS, ESCAPE OR RESCUE WINDOWS ARE REQUIRED TO HAVE A MINIMUM NET CLEAR OPEN-ABLE AREA OF 5.7 SQ. FT. (820.8 SQ IN). EXCEPTION: MAY BE REDUCED TO 5.0 SF (720 SQ IN) IF 44" OR LESS FROM EXTERIOR GROUND LEVEL TO SILL. THE MINIMUM NET CLEAR OPEN-ABLE HEIGHT DIMENSION MUST BE 24 INCHES. THE MINIMUM NET CLEAR OPEN-ABLE WIDTH DIMENSION MUST BE 20 INCHES. THEY MUST ALSO HAVE A FINISHED SILL HEIGHT (CLEAR OPENING) OF NOT MORE THAN 44 INCHES ABOVE THE FLOOR. IN ORDER TO MEET THE REQUIRED NET-CLEAR OPEN AREA SQUARE-FOOT OPENING, EITHER THE WIDTH OR HEIGHT OR BOTH MUST EXCEED THE MINIMUM DIMENSIONS THEREOF.

WHEN REPLACING EXISTING NONCONFORMING WINDOWS REQUIRED FOR EMERGENCY ESCAPE AND RESCUE THE REPLACEMENT WINDOWS MUST MEET THE

EMERGENCY ESCAPE AND RESCUE REPLACEMENT WINDOW OPENINGS SHALL HAVE A MINIMUM NET CLEAR OPENING OF 4 SQ. FT.; MINIMUM NET CLEAR OPENING HEIGHT OF 22 INCHES; MINIMUM NET CLEAR OPENING WIDTH OF 20 INCHES. MINIMUM SILL HEIGHT OF NOT MORE THAN 48 INCHES ABOVE THE FLOOR OR THE INSTALLATION OF ONE OR MORE PERMANENTLY AFFIXED STEPS EXTENDING THE FULL WIDTH OF THE WINDOW OPENING, CONSTRUCTED TO THE CURRENT ADOPTED IRC RISE AND RUN DIMENSIONAL REQUIREMENTS, SO THAT THE TOP STEP IS NO GREATER THAN 44 INCHES TO THE TOP OF THE SILL WHERE THE EXISTING ROUGH OPENING DOES NOT ALLOW FOR REPLACEMENT WINDOW DIMENSIONAL REQUIREMENTS THE ROUGH OPENING SHALL BE ENLARGED AND THE REPLACEMENT WINDOW SHALL MEET THE FULL EMERGENCY ESCAPE AND RESCUE OPENINGS PER IRC SECTION R310.1 THROUGH R310.5 OR IBC SECTION 1026 AS APPLICABLE FOR SCOPE OF PROJECT.

ADDITIONAL GLAZING REQUIREMENTS:

FOR MINIMUM LIGHT, ALL SLEEPING ROOMS AND OTHER HABITABLE ROOMS REQUIRE GLAZING EQUAL TO AT LEAST 8% OF THE FLOOR AREA OF THE ROOM; MINIMUM VENTILATION OF 4% OF THE FLOOR AREA. SEE THE INTERNATIONAL BUILDING OR RESIDENTIAL CODES AS APPLICABLE FOR EXCEPTIONS AND A COMPLETE LIST OF LIGHT AND VENTILATION REQUIREMENTS.

SAFETY GLAZING IS REQUIRED IN DOORS, STORM DOORS, RAILINGS, WITHIN 24 INCHES OF A DOOR, OR WHEN PANES ARE OVER 9 SQUARE FEET AND WITHIN 18 INCHES OF THE FLOOR. SEE THE INTERNATIONAL BUILDING OR RESIDENTIAL CODES FOR EXCEPTIONS AND A COMPLETE LIST OF SAFETY GLAZING



KASSIS DEVELOPMENT
2580 COUNTRY CLUB DRIVE CAMERON PARK,
EL DORADO COUNTY
APN: 082-391-002

Revision No	tes:	
Date	Description	

COPYRIGHT
THIS DRAWING IS AN INSTRUMENT OF SERVICE AND AS SUCH, REMAINS THE PROPERTY OF PIXELARCH LTD. PERMISSION FOR USE OR REPRODUCTION IS LIMITED AND CAN BE EXTENDED ONLY BY WRITTEN PERMISSION WITH OWNER, PIXELARCH LTD.

DEC. 07, 2022

1/4" = 1'-0"





PixelArch Itd. US Office:
24001 Calle De La Magdalena, unit 3896
Laguna Hills, CA 92653
Tel: (415) 316 7162 info@pixelarchltd.com
www.pixelarchltd.com

KASSIS DEVELOPMENT
2580 COUNTRY CLUB DRIVE CAMERON PA
EL DORADO COUNTY
APN: 082-391-002

Revision Notes:

COPYRIGHT THIS DRAWING IS AN INSTRUMENT OF SERVICE AND AS SUCH, REMAINS THE

PERMISSION WITH OWNER, PIXELARCH LTD.

PROPOSED WEST AND NORTH ELEVATION **BUILDING - C**


1/4" = 1'-0"

JAN. 19, 2023



FIRE-RESISTANCE RATED CONSTRUCTION:

- 1. IN COMBUSTIBLE CONSTRUCTION, FIRE BLOCKING SHALL BE PROVIDED TO CUT OFF ALL CONCEALED DRAFT OPENINGS [BOTH VERTICAL AND HORIZONTAL] AND TO FORM AN EFFECTIVE FIRE BARRIER BETWEEN STORIES, AND BETWEEN A TOP STORY AND THE ROOF SPACE, R302.11.
- 2. IN COMBUSTIBLE CONSTRUCTION WHERE THERE IS USABLE SPACE BOTH ABOVE AND BELOW THE CONCEALED SPACE OF A FLOOR/CEILING ASSEMBLY. DRAFT STOPS SHALL BE INSTALLED SO THAT THE AREA OF THE CONCEALED SPACE DOSE NOT EXCEED 1,000 SQUARE FEET. DRAFT STOPPING SHALL DIVIDE THE



US Office:
24001 Calle De La Magdalena, unit 3896
Laguna Hills, CA 92653
Tel: (415) 316 7162 info@pixelarchltd.com
www.pixelarchltd.com

KASSIS DEVELOPMENT
2580 COUNTRY CLUB DRIVE CAMERON PARK, CA 95682
EL DORADO COUNTY
APN: 082-391-002

Revision Notes:

Date Description

COPYRIGHT
THIS DRAWING IS AN INSTRUMENT OF
SERVICE AND AS SUCH, REMAINS THE
PROPERTY OF PIXELARCH LTD. PERMISSION
FOR USE OR REPRODUCTION IS LIMITED AND
CAN BE EXTENDED ONLY BY WRITTEN
PERMISSION WITH OWNER, PIXELARCH LTD.

Drawing Title:

INTERIOR & EXTERIOR PARTITION WALLS DETAILS

1/4" = 1'-0"

JAN. 19, 2023

Page No. :

KASSIS DEVELOPMENT CIVIL PLANS 2580 COUNTRY CLUB DRIVE CAMERON PARK, CA 95682

SITE INFORMATION

ASSESSOR PARCEL NUMBER (APN) 082-391-002-000
PARCEL ID: 082391002
TAX RATE AREA (TRA) 054009

PROPERTY ADDRESS 2580 COUNTRY CLUB DR CAMERON PARK CA 95682

PROPERTY TYPE VACANT MULTI -RES LAND (4 & 4+ UNITS ALLOWED)

LOT SIZE (ACRES) 0.58

LOT SIZE (SQ. FT.) 24,578

ASMT DESCRIPTION LOT 32 CAMERON PK N 5

SUBDIVISION TRACT NUMBER: 36

SUBDIVISION TRACT NAME: CAMERON PARK NORTH UNIT NO 5

JURISDICTION: COUNTY OF EL DORADO

WATER: EL DORADO IRRIGATION DIST
FIRE: CAMERON PARK CSD FIRE

SCOPE OF WORK:

PRELIMINARY CIVIL PLANS FOR THE MULTI-UNIT DEVELOPMENT

SHEET LIST

1 GENERAL NOTES 2 EXISTING CONDITIONS

C3 PROPOSED GRADE (GRADING PLAN)

C3 PROPOSED GRADE (GRADING PLAN)
C4 EROSION & SEDIMENTATION CONTROL

C5 EROSION & SEDIMENTATION CONTROL DETAILS

C6 DRAINAGE AREA MAP


C7 STORMWATER MANAGEMENT SYSTEM

C8 STORMWATER STRUCTURES

C9 UTILITY PLAN
C10 SITE PLAN

LANDSCAPE PLAN








PixelArch ltd.

Office: 24001 Calle De La Magdalena, unit 3896 Laguna Hills, CA 92653 Tel: (415) 316 7162 info@pixelarchitd.com



N.T.S

KASSIS DEVELOPMENT
2580 COUNTRY CLUB DR, CAMERON PARK
CA 95682

C0
Cover Page

Scale:

Date:

Page No. :

GENERAL NOTES:

- THESE DRAWINGS HAVE BEEN PREPARED FOR THE SOLE USE OF THE OWNER AND BASED THE OWNER'S COMMENTS AND REQUEST. THE ENGINEER ACCEPTS NO RESPONSIBILITY OR LIABILITY FOR THE ACCURACY OF THE EXISTING CONDITIONS, PLAN REVIEW. AND COMPLETENESS OF THE INFORMATION SHOWN ON THE PLANS.
- ALL MATERIALS AND CONSTRUCT ION PROCEDURES WITHIN THE SCOPE OF THIS CONTRACT SHALL COMPLY WITH:
 A. CURRENT CITY OF CAMERON PARK BUILDING PERMIT APPLICATIONS AND STANDARDS AS OF THE DATE OF
- B. THE MOST CURRENT EDITION OF THE STATE OF CALIFORNIA DEPARTMENT OF TRANSPORTATION (CALTRANS) STANDARD SPECIFICATIONS.
- C. THE ADOPTED EDITION OF THE STATE OF CALIFORNIA BUILDING CODES ALONG WITH THE SPECIFIC CODE MODIFICATIONS ADOPTED BY THE EL DORADO COUNTY.
- CONTRACTOR SHALL PROCURE ALL PERMITS AND LICENSES, PAY ALL CHARGES, FEES, AND TAXES AND GIVE ALL NOTICES NECESSARY AND INCIDENTAL TO THE DUE AND LAWFUL PROSECUTION OF THE WORK.
- ANY EXISTING OFF-SITE IMPROVEMENTS THAT ARE DAMAGED OR UNDERCUT BY THE CONTRACTOR'S OPERATIONS SHALL BE REPAIRED OR REPLACED AS DIRECTED BY THE ENGINEER AND APPROVED BY THE OWNER OF THE EXISTING IMPROVEMENT AT THE CONTRACTOR'S EXPENSE (NO SEPARATE PAY ITEM).
- WORK COMPLETED BY THE CONTRACTOR WHICH HAS NOT RECEIVED A WORK ORDER OR CONSENT OF THE OWNER OR ENGINEER WILL BE SUBJECT TO REMOVAL AND REPLACEMENT BY AND AT THE EXPENSE OF THE CONTRACTOR.
- CONTRACTOR IS RESPONSIBLE FOR REMOVAL OF ALL WASTE MATERIALS UPON PROJECT COMPLETION. THE CONTRACTOR SHALL NOT PLACE ANY WASTE MATERIAL IN ANY 100-YEAR FLOOD PLAIN WITHOUT FIRST OBTAINING AN APPROVED FLOOD PLAIN DEVELOPMENT PERMIT.
- BARRICADES AND WARNING SIGNS SHALL CONFORM TO THE CALTRANS MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES AND SHALL BE LOCATED TO PROVIDE MAXIMUM PROTECTION TO THE PUBLIC AS WELL AS CONSTRUCTION PERSONNEL AND EQUIPMENT WHILE PROVIDING CONTINUOUS TRAFFIC FLOW AT ALL TIMES DURING CONSTRUCTION. THE CONTRACTOR IS RESPONSIBLE FOR MAINTAINING ALL DEVICES DURING CONSTRUCTION
- CONTRACTOR IS REQUIRED TO VERIFY PROJECT ELEVATIONS. THE TERM "MATCH EXISTING" SHALL BE UNDERSTOOD TO SIGNIFY BOTH HORIZONTAL AND VERTICAL ALIGNMENT.
- WHEN MATCHING EXISTING PAVEMENTS. CURBS, DRIVES, AND WALKS, THEY SHALL BE SAW CUT FULL DEPTH AND REMOVED TO ALLOW FOR PROPOSED CONSTRUCTION. IF ANY EXISTING JOINT IS ENCOUNTERED, PRECAUTION SHALL BE TAKEN DURING REMOVAL OF CONCRETE SO AS NOT TO DAMAGE EXISTING DOWELS. ALL EXISTING DOWELS SHALL BE EXPOSED AND CLEANED.
- 10. ALL "COMPACTED SUBGRADE" SHALL CONSIST OF NATIVE MATERIAL SCARIFIED TO A MINIMUM DEB OF SIX INCHES AND COMPACTED TO 95% DENSITY ACCORDING TO ASTM D-698 AND TESTED BY ASTM D-2922.
- 11. ALL "FLEXIBLE BASE" SHALL BE TYPE "A", GRADE 1, COMPACTED TO 100% MODIFIED DENSITY AT A MOISTURE CONTENT BETWEEN -2 AND +3 OF OPTIMUM PERCENT MOISTURE ACCORDING TO ASTM D-1557 (MODIFIED PROCTOR) AND TESTED BY ASTM D-2922.
- 12. ASPHALT PAVEMENT SHALL BE THE TYPE SPECIFIED ON THE PLANS AND ACCORDING TO CALTRANS "HOT MIX ASPHALT CONCRETE PAVEMENT"
- 13. PRIME COAT USING MC-30 AT A RATE OF 0.2 GALLONS PER SQUARE YARD SHALL BE PLACED OVER PREPARED BASE AT LEAST ONE DAY PRIOR TO LAYING ASPHALTIC CONCRETE PAVEMENT. ANY NECESSARY TACK COAT SHALL BE MC-30 AT 0.05 GALLONS PER SQUARE YARD.
- 14. CONCRETE SHALL BE CLASS "A" UNLESS OTHERWISE ON PLANS.
- 15. REINFORCING STEEL SHALL BE FROM NEW BILLET. ALL DIMENSIONS RELATING TO REINFORCING STEEL ARE TO
- CENTER OF BARS EXCEPT WHEN REFERRING TO CLEARANCE.
- 16. ALL SAWED JOINTS SHALL BE SAWED WITHIN 24 HOURS OF POURING.
- 17. ORDINARY COMPACTION CONTROL IS REQUIRED ON THIS PROJECT.
- 18. ALL ROLLING FOR COMPACTION OF ASPHALTIC CONCRETE PAVEMENT SHALL BE COMPLETED BEFORE THE MIXTURE TEMPERATURE DROPS BELOW 175 DEG. (F).
- 19. CONTRACTOR AGREES TO ASSUME SOLE AND COMPLETE RESPONSIBILITY FOR JOB SITE CONDITIONS DURING THE CONSTRUCTION OF THE PROJECT, INCLUDING SAFETY OF ALL PERSONS AND PROPERTY; THAT THIS REQUIREMENT SHALL APPLY CONTINUOUSLY AND SHALL NOT BE LIMITED TO THE NORMAL WORKING HOURS; AND THAT THE CONTRACTOR SHALL DEFEND, INDEMNIFY AND HOLD THE OWNERS AND THE ENGINEER AND HIS EMPLOYEES, PARTNERS, OFFICES, DIRECTORS, OR CONSULTANTS, HARMLESS FROM ANY AND ALL LIABILITY, REAL OR ALLEGED, I N CONNECTION WITH THE PERFORMANCE OF THE WORK ON THIS PROJECT, EXCEPTING FROM LIABILITY ARISING FROM SOLE NEGLIGENCE OF THE OWNER OR ENGINEER, ENGINEER'S DIRECTORS, OFFICERS, EMPLOYEES, OR CONSULTANTS
- 20. ALL CMP (CORRUGATED METAL PIPE) USED ON THIS PROJECT SHALL HAVE A MANNING'S "N" VALUE OF 0.024, UNLESS OTHERWISE SHOWN ON PLANS.
- 21. ALL COST ASSOCIATED WITH THE REMOVAL, REPLACEMENT AND TESTING SHALL BE PAID BY THE CONTRACTOR.
- 22. ALL PVC SLEEVES SHALL BE INSTALLED THREE FEET (3') BELOW FINISHED GRADE AND ENDS SHALL BE MARKED SO THAT LOCATIONS OF SLEEVES CAN BE EASILY IDENTIFIED.

EROSION / SEDIMENTATION CONTROL NOTES:

- AT A MINIMUM, THESE CONTROLS SHALL CONSIST OF ROCK BERMS AND/OR SILT FENCES CONSTRUCTED PARALLEL TO AND DOWN GRADIENT FROM THE TRENCHES. THE ROCK BERMS OR SILT FENCES SHALL BE INSTALLED IN A MANNER SUCH THAT ANY RAINFALL RUNOFF SHALL BE FILTERED. HAY BALES SHALL NOT BE USED FOR TEMPORARY EROSION AND SEDIMENTATION CONTROLS.
- ALL TEMPORARY EROSION AND SEDIMENTATION CONTROLS MUST BE INSTALLED PRIOR TO CONSTRUCTION AND SHALL BE MAINTAINED DURING CONSTRUCTION BY THE CONTRACTOR. THE CONTRACTOR SHALL REMOVE THE CONTROLS WHEN VEGETATION IS ESTABLISHED AND THE CONSTRUCTION AREA IS STABILIZED. ADDITIONAL PROTECTION MAY BE REQUIRED IF EXCESSIVE SOLIDS ARE BEING DISCHARGED FROM THE SITE.
- ALL TEMPORARY EROSION AND SEDIMENTATION CONTROLS SHALL BE REMOVED BY THE CONTRACTOR AT FINAL ACCEPTANCE OF THE PROJECT BY THE OWNER / ENGINEER.
- PLACEMENT OF TEMPORARY EROSION AND SEDIMENTATION CONTROLS SHALL BE IN ACCORDANCE WITH THE CONSTRUCTION PLANS. ACTUAL LOCATIONS MAY VARY SLIGHTLY FROM THE PLANS, BUT WILL BE VERIFIED BY THE ENGINEER/INSPECTOR IN THE FIELD PRIOR TO CONSTRUCTION. THE CONTRACTOR SHALL INSPECT THE CONTROLS AT WEEKLY INTERVALS AND AFTER EVERY SIGNIFICANT RAINFALL TO INSURE DISTURBANCE OF THE STRUCTURES HAS NOT OCCURRED. SEDIMENT DEPOSITED AFTER A RAINFALL SHALL BE REMOVED FROM THE SITE OR PLACED IN AN ENGINEER APPROVED DESIGNATED DISPOSAL AREA.
- CONTRACTOR SHALL BE RESPONSIBLE TO INSURE THAT NO EROSION CONTROL MEASURES BLOCK THE DRAINAGE SYSTEM FROM WORKING AS DESIGNED

- LOCATION AND DEPTH OF EXISTING UTILITIES SHOWN HERE ARE APPROXIMATE ONLY. ACTUAL LOCATIONS AND RESPONSIBLE FOR PROTECTION OF ALL EXISTING UTILITIES ENCOUNTERED DURING CONSTRUCTION, INCLUDING THOSE NOT SHOWN ON THE DRAWINGS.
- ANY EXISTING UTILITIES, ON OR OFF THE SITE, THAT ARE DAMAGED OR UNDERCUT BY THE CONTRACTOR'S OPERATIONS SHALL BE REPAIRED OR REPLACED AS DIRECTED BY THE ENGINEER AND APPROVED BY THE RESPECTIVE UTILITY COMPANY AT THE CONTRACTOR'S EXPENSE
- DUE TO FEDERAL REGULATIONS TITLE 49, PART 192(8), GAS COMPANIES MUST MAINTAIN ACCESS TO GAS VALVES. AT ALL TIMES. THE CONTRACTOR MUST PROTECT THE WORK AROUND ANY GAS VALVES THAT ARE IN THE PROJECT AREA. CONTRACTOR SHALL REFERENCE CITY UTILITIES PLANS FOR FINAL ELECTRICAL LINE DESIGNS AND LAYOUT.

SEWER NOTES:

- 1. THE CONTRACTOR SHALL MAINTAIN SERVICE TO EXISTING SANITARY SEWERS AT ALL TIMES DURING CONSTRUCTION
- 2. A MINIMUM OF SIX INCHES (6") WASTEWATER PIPE AND FITTINGS (ASTM D3034 SDR 26) ARE REQUIRED ON ALL NEW INSTALLATION
- ALL RESIDENTIAL WASTEWATER SERVICE LATERALS SHALL BE EXTENDED TO THE PROPERTY LINE AND A CLEANOUT SHALL BE INSTALLED AT THE PROPERTY LINE. SERVICES TO LOTS WILL EXTEND THROUGH 10-FOOT (10') UTILITY EASEMENT

- SECONDARY BACKFILL OF SEWER LINES SHALL GENERALLY CONSIST OF MATERIALS REMOVED FROM THE TRENCH AND SHALL BE FREE FROM BRUSH, DEBRIS, AND TRASH, NO ROCKS OR STONES HAVING ANY DIMENSION LARGER THAN FOUR INCHES (4") AT THE LARGEST DIMENSION.
- ALL SEWER PIPES SHALL HAVE COMPRESSION OR MECHANICAL JOINTS
- ALL MANHOLES SHALL BE CONSTRUCTED OF FOUR FOOT DIAMETIER (4' DIA) REINFORCED CONCRETE PIPE MEETING THE REQUIREMENTS OF ASTM SPECIFICATIONS C-478 OR POUR MONOLITHICALLY. CONCRETE RINGS SHALL BE USED TO ADJUST MANHOLE HEIGHTS TO MATCH EXISTING GRADE, MAXIMUM HEIGHT SHALL NOT EXCEED TWELVE INCHES (12"). CAST IRON FRAMES AND COVERS SHALL CONFORM TO ASTM SPECIFICATIONS A-4B CLASS 30.
- MANHOLE RINGS AND COVERS SHALL WEIGH A MINIMUM OF 460 POUNDS. OUTSIDE DIAMETER OF THE LID SHALL BE THIRTY-TWO INCHES (32"). MANHOLES SHALL BE CONSTRUCTED OF OR LINED WITH A CORROSION MATERIAL RESISTANT MATERIAL. WHERE NEW CONSTRUCTION TIES INTO AN EXISTING MANHOLE. THE EXISTING MANHOLE MUST BE LINED, COATED, OR REPLACED WITH A CORROSION RESISTANT MATERIAL
- 8. LIDS ARE TO BE SOLID WITH NO PICK HOLES.
- MANHOLE COVERS SHALL BE MARKED "SANITARY SEWER". PIPE CONNECTIONS TO MANHOLES SHALL BE CORED AND WATER TIGHT MANHOLE CONNECTORS KOR-N-SEAL I & II OR EQUAL ASTM C.
- 10. ALL MANHOLES SHALL BE CONSTRUCTED SO THAT THE TOP OF THE RING IS 2" ABOVE THE SURROUNDING GROUND EXCEPT WHEN LOCATED IN PAVED AREAS. IN PAVED AREAS, THE MANHOLE RING SHALL BE FLUSH WITH PAVEMENT.
- 11. WASTEWATER PIPE CONNECTIONS TO MANHOLES SHALL BE MADE WATER TIGHT USING A GASKET AROUND THE PIPE. THE GASKET PIPE SHALL THEN BE GROUTED INTO PLACE, USING A STIFF MIX NON-SHRINK GROUT, VIA KNOCKED OUT HOLES IN CONCRETE PIPE WALLS. STEPS SHALL NOT BE PROVIDED.
- 12. WASTEWATER LINES SHALL BE TESTED FROM MANHOLE TO MANHOLE
- 13. IN AREAS WHERE A NEW WASTEWATER MANHOLE IS TO BE CONSTRUCTED OVER AN EXISTING WASTEWATER SYSTEM, IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO TEST THE EXISTING MANHOLES BEFORE CONSTRUCTION. AFTER PROPOSED MANHOLE HAS BEEN BUILT, THE CONTRACTOR SHALL RE-TEST THE EXISTING SYSTEM TO THE SATISFACTION OF THE CONSTRUCTION INSPECTOR. (NO SEPARATE PAY ITEM)
- 14. WHERE THE MINIMUM NINE-FOOT (9') SEPARATION DISTANCE BETWEEN WASTEWATER LINES AND WATER LINES / MAINS CANNOT BE MAINTAINED, THE INSTALLATION OF WASTEWATER LINES SHALL BE IN STRICT ACCORDANCE WITH TCEQ REGULATIONS. THE WASTEWATER LINE SHALL BE CONSTRUCTED OF CAST IRON, DUCTILE IRON, OR PVC MEETING THE ASTM SPECIFICATION FOR BOTH PIPES AND JOINTS OF 150 PSI AND SHALL BE IN ACCORDANCE WITH 30 TAC 217. 53 (D)(3)(A)(I).
- 15. WATER JETTING THE BACKFILL WITHIN A STREET WILL NOT BE PERMITTED. SANITARY SEWER TRENCHES SUBJECT TO TRAFFIC SHALL CONFORM TO THE CITY CONSTRUCTION STANDARDS.
- NO TESTING WILL BE PERFORMED PRIOR TO 30 DAYS FROM COMPLETE INSTALLATION OF THE SANITARY SEWER LINES. THE FOLLOWING SEQUENCE WILL BE STRICTLY ADHERED TO:
- A. PULL MANDREL
- B. PERFORM AIR TEST
- C. CLEANING OF ANY DEBRIS
- D. FLUSHING OF SYSTEM
- E. TV INSPECTION (WITH IN 72 HOURS OF FLUSHING)
- A MINIMUM OF THREE FEET (3') OF COVER IS TO BE MAINTAINED OVER THE SANITARY SEWER MAIN AND LATERALS AT SUBGRADE, OTHERWISE CONCRETE ENCASEMENT WILL BE REQUIRED
- 18. CLEANOUTS SHALL BE PROVIDED AT THE END OF EACH LINE WHEN A MANHOLE IS NOT REQUIRED. A CI CLEANOUT CASTING ALAMO IRON WORKS NO. 813-45, OR APPROVED EQUAL SHALL BE USED.
- 19. EACH LOT OWNER SHALL BE RESPONSIBLE FOR VERIFYING THE DEPTH OF THE SEWER SERVICE STUB OUT, AND
- DETERMINE THE MINIMUM SERVICEABLE FINISHED FLOOR ELEVATION. 20. VERTICAL SEWER SERVICE STACKS SHALL BE REQUIRED WHERE THE TOP OF THE SEWER MAIN IS AT A DEPTH OF EIGHT FEET (8') OR GREATER, UNLESS SHOWN OTHERWISE ON PLANS.

- 1. ALL WATER MAINS SHALL BE AWWA C900 (CLASS 150 OR GREATER), DR18.
- 2. WATER SERVICES SHALL BE TYPE "K" SOFT COPPER CONFORMING TO ASTM SPECIFICATION B-88t OR LATEST
- 3. WATER MAIN SHALL HAVE A MINIMUM OF 36 INCHES OF COVER, EXCEPT THAT UNDER ROAD SIDE DITCHES AND
- ROAD CROSSING, ADDITIONAL COVER AND ENCASEMENT IS REQUIRED. 4. EACH UNIT WITHIN A DUPLEX, TRIPLEX, FOURPLEX, OR CONDOMINIUM SHALL BE PROVIDED WITH AN INDIVIDUAL
- WATER METER. A MASTER METER CAN BE CONSIDERED FOR SEPARATE BUILDINGS, HOWEVER, THOSE BUILDINGS MUST BE PLUMBED TO ALLOW SEPARATE METERS FOR FUTURE CONSIDERATION
- 5. CONTRACTOR WILL KEEP THE AREA ON TOP OF AND AROUND THE WATER METER BOX FREE OF ALL OBJECTS AND
- 6. SECONDARY BACKFILL OF WATER LINES SHALL GENERALLY CONSIST OF MATERIAL REMOVED FROM THE TRENCH AND SHALL BE FREE FROM BRUSH, DEBRIS AND TRASH OR STONES HAVING ANY DIMENSION LARGER THAN 4" INCHES AT THE LARGEST DIMENSION.
- HYDROSTATIC TESTING IS DONE FROM VALVE TO VALVE.
- NO METER BOXES TO BE SET IN DRIVEWAYS OR SIDEWALKS. ANY METER BOXES SET IN DRIVEWAYS OR SIDEWALKS WILL BE RELOCATED AT CONTRACTOR 'S AND/OR DEVELOPER'S EXPENSE.
- METER BOXES MUST BE SET AT THE PROPOSED GRADE. ANY METER BOXES THAT ARE NOT SET AT THE FINAL GRADE WILL BE ADJUSTED AT CONTRACTOR'S AND/OR DEVELOPER'S EXPENSE.
- 10. METER BOXES SHALL BE PLASTIC, WITH COVERS, BY DFW PLASTICS, INC. OR APPROVED EQUAL
- 11. BRASS STOPS FOR CONNECTING TUBING TO SERVICE CLAMPS SHALL BE MUELLER OR APPROVED EQUAL WITH
- COMPRESSION BY CC THREAD FITTINGS. 12. TAPPING SADDLES SHALL BE MUELLER OR APPROVED EQUAL DOUBLE STRAP WITH CC THREAD
- CONTRACTOR SHALL PLACE TRACER WIRE ON TOP OF THE WATER MAINS. TRACER WIRE SHOULD RUN FROM VALVE TO VALVE AND EXIT AT THE VALVE BOX. THE TRACER WIRE SHOULD BE ATTACHED TO THE TOP OF THE PIPE USING TAPE. EXCESS WIRE SHOULD BE LEFT WITHIN VALVE BOXES TO BE PLACED WITHIN LID OF COVER.

DRAINAGE NOTES

ENCOUNTERED.

- 1. ALL CONCRETE AND REINFORCING STEEL USED IN DRAINAGE STRUCTURES SHALL BE IN COMPLIANCE WITH THE CITY STANDARDS. CONCRETE SHALL BE CLASS A.
- 2. PIPES FOR STORM DRAINS SHALL BE CONCRETE PIPE IN SIZES AS SHOWN ON APPROVED PLANS. ALL CONCRETE PIPES SHALL BE RCP ASTM SPECIFICATION C76. WHERE ADDED STRENGTH OF PIPE IS NEEDED FOR TRAFFIC LOADS OVER MINIMUM COVER OR HAVE A MINIMUM COVER OF NOT LESS THAN ONE FOOT (1') OVER THE TOP OF THE PIPE. ALL PIPES SHALL HAVE INTEGRAL TONGUE AND GROOVE JOINTS . ALL CONCRETE PIPE BENDS OR FITTINGS FOR HORIZONTAL OR VERTICAL CHANGES IN ALIGNMENT, AND ALL SPECIAL FITTINGS, SHALL BE OF PREFABRICATED CONSTRUCTION USING RCP.
- 3. MANHOLE COVERS SHALL BE VULCAN FOUNDRY NUMBER VM-34, OR EQUAL, WITH 22 INCH (22") OPENING AND WEIGHT OF AT LEAST 240 POUNDS. THE COVER SHALL BE MARKED "STORM".
- ASPHALT COMPOUNDS SHALL CONSIST OF ASPHALT BASE, VOLATILE SOLVENTS, AND INERT FILTER. THE JOINT
- COMPOUND SHALL CONFORM TO THE STANDARDS OF THE TDHPT.
- MORTAR JOINT MIX SHALL BE COMPOSED OF ONE PART CEMENT OR PARTS OF MORTAR SAND. THE TRENCH WIDTH SHALL BE AT LEAST 15 INCHES (15") WIDER BUT NOT MORE THAN 21 INCHES (21") WIDER THAN
- THE OUTSIDE DIAMETER OF PIPE. TRENCH SHALL BE EXCAVATED VER CONDUIT, ABOVE WHICH POINT, TRENCH SIDES SHALL BE EXCAVATED AS NEAR TO VERTICAL AS POSSIBLE AND
- 8. A MINIMUM OF SIX INCHES (6") OF GRANULAR EMBEDMENT SHALL BE PLACED UNDER THE PIPE WHEN ROCK IS
- BACKFILL MATERIALS FOR TRENCHES NOT TO BE IN PROPOSED STREET AREA, EXISTING STREETS, OR WITHIN FIVE FEET (5') OF THE BACK OF CURB OR EDGE OF PAVEMENT MUST INCLUDE SPECIFIED EMBEDMENT MATERIAL AND MAY BE BACKFILLED WITH EXCAVATED MATERIALS THAT ARE VOID OF ROCKS AND OTHER OBJECTS LARGER THAN FOUR INCHES IN DIAMETER (4" DIA).
- 10. SECONDARY BACKFILL OF STORM DRAIN SHALL GENERALLY CONSIST OF MATERIALS REMOVED FROM THE TRENCH AND SHALL BE FREE FROM BRUSH, DEBRIS, AND TRASH, NO ROCKS OR STONES HAVING ANY DIMENSION LARGER THAN FOUR INCHES (4") AT THE LARGEST DIMENSION
- 11. MORTAR JOINT AREAS SHALL BE THOROUGHLY WETTED. THE LOWER ONE-HALFE (1/2) OF THE GROOVE SHALL BE PACKED WITH MORTAR FROM THE INTERIOR. THE REMAINING GROOVE AREA SHALL BE QUICKLY PACKED WITH MORTAR FROM THE EXTERIOR. A MORTAR BEAD SHALL BE FORMED AROUND THE PIPE JOINT. THE BEAD SHALL EXTEND A MINIMUM OF ONE INCH (1") ON EACH SIDE OF THE JOINT AND PROJECT OUTWARD A DISTANCE OF ONE INCH (1"). THE INSIDE OF PIPE JOINT SHALL BE FINISHED SMOOTH WITH THE INSIDE OF THE PIPE. THE JOINT SHALL BE PROTECTED FROM SUN AND AIR BY AN APPROVED WET WRAPPING OR WET OIL COVER FOR A MINIMUM OF 4B HOURS OR UNTIL BACKFILLED. JOINTS SHALL NOT BE MADE WHEN THE TEMPERATURE IS 40 DEG F OR BELOW.
- ASPHALT COMPOUND JOINTS SHALL BE MADE IN CONFORMANCE WITH MANUFACTURER'S RECOMMENDATIONS. THE PIPE SHALL BE DRY. SUFFICIENT COMPOUND SHALL BE PLACED IN THE GROOVE TO CAUSE SOME MATERIAL TO BE

SQUEEZED FROM JOINT WHEN PIPE IS SEATED. THE INSIDE OF PIPE JOINTS SHALL BE WIPED CLEAN AFTER JOINT

CONSTRUCTION NOTES:

DRAINAGE IMPROVEMENTS SUFFICIENT TO MITIGATE THE IMPACT OF CONSTRUCTION SHALL BE INSTALLED PRIOR TO ADDING IMPERVIOUS COVER.

- ALL ROADWAY COMPACTION TESTS SHALL BE THE RESPONSIBILITY OF THE DEVELOPER'S GEO-TECHNICAL ENGINEER. FLEXIBLE BASE OR FILL MATERIAL, INCLUSIVE OF SUBGRADE, SHALL BE COMPACTED AS A SPECIFIED AND TESTED FOR DENSITY AND MOISTURE
- ASPHALTIC CONCRETE PAVEMENT SHALL BE TYPE "D" HOT MIX ASPHALT AS DEFINED IN CALTRANS' STANDARD
- THE ASPHALTIC CONCRETE SURFACE COURSE SHALL BE PLANT MIXED, HOT LAID TYPE "D" MEETING THE SPECIFICATION REQUIREMENTS OF CALTRANS. THE MIX SHALL BE DESIGNED FOR A STABILITY OF AT LEAST 35 AND SHALL BE COMPACTED TO BETWEEN 91 AND 95 PERCENT OF THE MAXIMUM THEORETICAL DENSITY. THE ASPHALT CEMENT CONTENT BY PERCENT OF TOTAL MIXTURE WEIGHT SHALL FALL WITHIN A TOLERANCE OF +0.5 PERCENT FROM A SPECIFIC MIX DESIGN.

 ALL UTILITY TRENCH COMPACTION TESTS WITHIN THE STREET PAVEMENT SECTION SHALL BE THE RESPONSIBILITY OF THE DEVELOPER'S GEO-TECHNICAL ENGINEER. FILL MATERIAL SHALL BE PLACED IN UNIFORM LAYERS NOT TO EXCEED TWELVE INCHES (12") LOOSE. EACH LAYER OF MATERIAL SHALL BE COMPACTED TO A MINIMUM 95% DENSITY AND TESTED FOR DENSITY AND MOISTURE.

- DUE TO CONSTRUCTION OF NEW RIGHT-OF-WAY CONSTRUCTION:
- SAWCUT EXISTING STREET AND MATCH TO NEW CONSTRUCTION. SAWCUT EXISTING CURB TO TIE INTO EXISTING CONSTRUCTION.

CONSTRUCTION STABILIZED ENTRANCE

- SAWCUT CURB FOR CONSTRUCTION ENTRANCE.
- STABILIZED CONSTRUCTION AREA SHALL BE CONSTRUCTED OF 3"X5" ROCK TO BE PLACED A MINIMUM LENGTH OF 25 FEET AND MAINTAINED SO THAT CONSTRUCTION DEBRIS DOES NOT FALL WITH IN THE CITY RIGHT-OF-'WAY. RIGHT-OF-WAY MUST BE CLEARED FROM MUD, ROCKS, ETC. AT ALL TIMES.

- THE CONTRACTOR SHALL FURNISH AND INSTALL ALL REGULATORY AND WARNING SIGNS, STREET NAME SIGNS AND SIGN MOUNTS IN ACCORDANCE WITH APPROVED ENGINEERING PLANS. THE CITY WILL INSPECT ALL SIGNS AT FINAL
- THE CONTRACTOR SHALL INSTALL ALL PAVEMENT MARKINGS IN ACCORDANCE WITH APPROVED ENGINEERING PLANS. THE CONTRACTOR SHALL NOTIFY THE CITY AT LEAST TWIENTY-FOUR (24) HOURS PRIOR TO THE INSTALLATION OF ALL SEALER AND FINAL MARKINGS. THE CITY WILL INSPECT ALL MARKINGS AT FINAL APPLICATION

- THE WEDGE ANCHOR STEEL SYSTEM AND THIN-WALLED TUBING POST SHALL BE USED FOR SIGNS WITH UP TO 10 SQUARE FEET OF SIGN AREA. MATERIALS AND INSTALLATION SHOULD FOLLOW THE CALTRANS TRAFFIC
- THE TRIANGULAR SLIP BASE SYSTEM AND 10 BWG TUBING POST SHALL BE USED FOR SIGNS THAT HAVE 10 TO 16 SQUARE FEET OF SIGN AREA. MATERIALS AND INSTALLATION SHOULD FOLLOW THE CALTRANS TRAFFIC
- OBJECT MARKERS MATERIALS AND INSTALLATION SHOULD FOLLOW THE CALTRANS TRAFFIC STANDARDS.

 SIGN MATERIALS INCLUDING ALUMINUM SIGN BLANKS AND SIGN FACE MATERIALS SHOULD FOLLOW THE CALTRANS TRAFFIC STANDARDS.

SEQUENCE OF CONSTRUCTION 1. INSTALL EROSION CONTROLS PER APPROVED PLAN.

- TEMPORARY CONTROLS TO BE INSPECTED AND MAINTAINED WEEKLY AND PRIOR TO ANTICIPATED RAINFALL EVENTS, AND AFTER RAINFALL EVENTS, AS NEEDED. CONTRACTOR/OWNER SHALL PROVIDE A CONTACT NAME AND NUMBER FOR EROSION CONTROL ISSUES.
- CONDUCT DEMOLITION ACTIVITIES, IF APPLICABLE
- CONDUCT GRADING ACTIVITY IN R.O.W. FOR STREET CONSTRUCTION. CONDUCT TRENCHING ACTIVITY FOR WATER AND WASTEWATER IMPROVEMENTS.
- RE-VEGETATE DISTURBED AREAS.
- REMOVE EROSION CONTROLS (AS APPLICABLE) WITH COORDINATION OF OWNER REPRESENTATIVE AND ENGINEER.

- A. NO STREETS SHALL BE DESIGNED HAVING A SLOPE OF LESS THAN 0.40 FEET PER 100 FEET.
 - MAXIMUM VERTICAL GRADE AND MAXIMUM RADIUS LENGTH: 1. MAJOR ROAD/ARTERIAL STREET: 6% MAX. VERTICAL GRADE; MAX. RADIUS LENGTH 383' 2. COLLECTOR STREET: 6% MAX. VERTICAL GRADE; MAX. RADIUS LENGTH 288' 3. MINOR STREET: 60 FOOT R.O.W.: 6% MAX. VERTICAL GRADE; MAX. RADIUS LENGTH 288 FOOT
- TRAFFIC BARRIERS SHALL BE USED TO ROUTE, STOP, OR REDIRECT THE FLOW OF TRAFFIC AROUND DANGEROUS

50 FOOT R.O.W.: 10% MAX. VERTICAL GRADE; MAX. RADIUS LENGTH 100 FOOT

ENVIRONMENTS AND TO ALERT PEDESTRIANS AND LOWER VEHICLE TRAFFIC OF NEARBY DANGERS. THE MINIMUM PAVEMENT REQUIREMENTS FOR STREETS SHALL BE AS FOLLOWS APPROVED BY THE CITY ENGINEER:

STREET CLASSIFICATION	35 PI OR LESS	MORE THAN 35 PI	
1. FOR RESIDENTIAL (MINOR) ASPHALT STREETS			
BASE OR STRUCTURAL EQUIVALENT MINIMUM	8"	12"	
ASPHALT THICKNESS TYPE D OR AS APPROVED	1 1 "	2"	
2. FOR COLLECTOR ASPHALT STREETS			
BASE OR STRUCTURAL EQUIVALENT MINIMUM ASPHALT THICKNESS TYPE D OR AS APPROVED 2"	10"	14"	
3. FOR MAJOR ROAD/ARTERIAL STREETS			
BASE OR STRUCTURAL EQUIVALENT MINIMUM	12"	16"	
ASPHALT THICKNESS TYPE D OR AS APPROVED	2"	2"	

SOILS TESTING AND PAVEMENT DESIGN RECOMMENDATION FROM AN INDEPENDENT TESTING LABORATORY WILL BE REQUIRED TO DETERMINE IF ANY LIME STABILIZATION OR ADDITIONAL BASE OR PAVEMENT THICKNESS IS

GEOTECHNICAL STUDY & PAVEMENT DESIGN:


- RECOMMEND THE TOP 6" OF THE FINISHED SUBGRADE SOILS DIRECTLY BENEATH THE PAVEMENT BE CHEMICALLY
- CHEMICAL TREATMENT SHALL CONSIST OF LIME APPLIED AT A RATE OF ABOUT 6% 7%. WHICH EQUATES TO ABOUT 30 - 35 LBS OF LIME (DRY WEIGHT) PER SQUARE YARD PER 6" TREATED DEPTH
- PAVEMENT DESIGN A. RIGID PAVEMENT
 - a. REINFORCED CONCRETE 6" b. TREATED SUBGRADE - 6"
 - B. FLEXIBLE PAVEMENT: a. ASPHALT CONCRETE - 2.5"
 - b. BASE MATERIAL 10" c. TREATED SUBGRADE - 6"

PixelArch ltd.

nfo@pixelarchItd.com

www.pixelarchltd.com


24001 Calle De La Magdalena, unit 3896 Laguna Hills, CA 92653





N.T.S.


CAMERON DEVELOPMENT DR. CLUB KASSIS DE 2580 COUNTRY C CA 95682

C1 General Notes










NOTES

- ROCK BERM IS RECOMMENDED TO PREVENT SEDIMENT IN SILT-LADEN SHEET FLOW AND CAN BE USED AT THE TOE OF FILL OR ON SIDE SLOPES ABOVE WATERWAYS OR DRAINAGE CHANNELS.
- USE ONLY OPEN GRADED ROCK 75 to 125 mm (3 to 5") DIAMETER FOR ALL CONDITIONS.
 THE ROCK BERM SHALL BE SECURED WITH A WOVEN WIRE SHEATHING HAVING MAXIMUM 25 mm (1") OPENING AND MINIMUM WIRE DIAMETER OF 12.9 mm (20 GAUGE).
- 4. THE ROCK BERM SHALL BE INSPECTED DAILY OR AFTER EACH RAIN, AND THE STONE AND/OR FABRIC CORE-WOVEN SHEATHING SHALL BE REPLACED WHEN THE STRUCTURE CEASES TO FUNCTION AS INTENDED, DUE TO SEDIMENT ACCUMULATION AMONG THE ROCKS, WASHOUT, CONSTRUCTION TRAFFIC DAMAGE, ETC.
- 5. IF SEDIMENT REACHES A DEPTH EQUAL TO ONE-THIRD THE HEIGHT OF THE BERM OR 150 mm (6"), WHICHEVER IS LESS, THE SEDIMENT SHALL BE REMOVED AND DISPOSED OF ON AN APPROVED SITE AND IN A MANNER THAT WILL NOT CREATE A SEDIMENTION PROBLEM.
- 6. WHEN THE SITE IS COMPLETELY STABILIZED, THE BERM AND ACCUMULATED SEDIMENT SHALL BE REMOVED AND DISPOSED OF IN AN APPROVED MANNER.


ROCK BERM (OPTIONAL)



VIOTES


- 1. STONE SIZE: 75-125 mm (3-5") OPEN GRADED ROCK.
- 2. LENGTH: AS EFFECTIVE BUT NOT LESS THAN 6 m (20').
- 3. THICKNESS: NOT LESS THAN 200 mm (8").
- 4. WIDTH: NOT LESS THAN FULL WIDTH OF ALL POINTS OF INGRESS/EGRESS.
- 5. WASHING: WHEN NECESSARY, VEHICLE WHEELS SHALL BE CLEANED TO REMOVE SEDIMENT PRIOR TO ENTRANCE ONTO PUBLIC ROADWAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH CRUSHED STONE AND DRAINS INTO AN APPROVED TRAP OR SEDIMENT BASIN. ALL SEDIMENT SHALL BE PREVENTED FROM ENTERING ANY STORM DRAIN, DITCH OR WATERCOURSE USING APPROVED METHODS.
- 6. MAINTENANCE: THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION THAT WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC ROADWAY. THIS MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE AS CONDITIONS DEMAND, AS WELL AS REPAIR AND CLEAN OUT OF ANY MEASURE DEVICES USED TO TRAP SEDIMENT. ALL SEDIMENTS THAT IS SPILLED, DROPPED, WASHED OR TRACKED ONTO PUBLIC ROADWAY MUST BE REMOVED IMMEDIATELY.
- 7. DRAINAGE: ENTRANCE MUST BE PROPERLY GRADED OR INCORPORATE A DRAINAGE SWALE TO PREVENT RUNOFF FROM LEAVING THE CONSTRUCTION SITE.

STABILIZED CONSTRUCTION ENTRANCE



- 1. STEEL OR WOOD POSTS WHICH SUPPORT THE SILT FENCE SHALL BE INSTALLED ON A SLIGHT ANGLE TOWARD THE ANTICIPATED RUNOFF SOURCE. POST MUST BE EMBEDDED A MINIMUM OF 300 mm (12 INCHES). IF WOOD POSTS CANNOT ACHIEVE 300 mm (12 inches) DEPTH, USE STEEL POSTS.
- 2. THE TOE OF THE SILT FENCE SHALL BE TRENCHED IN WITH A SPADE OR MECHANICAL TRENCHER, SO THAT THE DOWNSLOPE FACE OF THE TRENCH IS FLAT AND PERPENDICULAR TO THE LINE OF FLOW.
- 3. THE TRENCH MUST BE A MINIMUM OF 150 mm (6 inches) DEEP AND 150 mm (6 inches) WIDE TO ALLOW FOR THE SILT FENCE FABRIC TO BE LAID IN THE GROUND AND BACKFILLED WITH COMPACTED MATERIAL.
- 4. SILT FENCE FABRIC SHOULD BE SECURELY FASTENED TO EACH STEEL OR WOOD SUPPORT POST OR TO WOVEN WIRE, WHICH IS IN TURN ATTACHED TO THE STEEL OR WOOD FENCE POST.
- 5. INSPECTION SHALL BE MADE WEEKLY OR AFTER EACH RAINFALL EVENT AND REPAIR OR REPLACEMENT SHALL BE MADE PROMPTY AS NEEDED.
- 6. SILT FENCE SHALL BE REMOVED WHEN THE SITE IS COMPLETELY STABILIZED SO AS NOT TO BLOCK OR IMPEDE STORM FLOW OR DRAINAGE.
- 7. ACCUMULATED SILT SHALL BE REMOVED WHEN IT REACHES A DEPTH OF 150 mm (6 inches). THE SILT SHALL BE DISPOSED OF ON AN APPROVED SITE AND IN SUCH A MANNER THAT WILL NOT CONTRIBUTE TO ADDITIONAL SILTATION.


SILT FENCE




NOTES:

1. USE EROSION CONTROL BLANKETS AS TEMPORARY, DEGRADABLE, ROLLED EROSION CONTROL PRODUCTS TO REDUCE SOIL EROSION AND ASSIST IN THE ESTABLISHMENT AND GROWTH OF VEGETATION.

EROSION CONTROL BLANKET (OPTIONAL)








PixelArch ltd.

24001 Calle De La Magdalena, unit 3896 Laguna Hills, CA 92653 Tel: (415) 316 7162


Tel: (415) 316 7162 info@pixelarchltd.com www.pixelarchltd.com





KASSIS DEVELOPMENT
2580 COUNTRY CLUB DR, CAMERON PARK,
CA 95682

C5
Erosion &
Sedimentaion
Control Details

Page No. :







SCALE: 1" = 20'

PROPOSED

Average recurrence interval (years)

- 1

--- 5

--- 10

- 25

--- 50 ---- 100 — 200 — 500

- 1000

DRAIN AREA	AREA	IMPERVIOUS	PERVIOUS	T _C	RUNOFF	5-YR STORI	M RUNOFF	10-YR STORM	1 RUNOFF	25-YR STORI	M RUNOFF	100-YR STOR	M RUNOFF
NO.	(ACRES)	(ACRES - %)	(ACRES - %)	(MIN)	COEFF. C	PEAK (CFS)	INTENSITY (IN/HR)	PEAK (CFS)	INTENSITY (IN/HR)	PEAK (CFS)	INTENSITY (IN/HR)	PEAK (CFS)	INTENSITY (IN/HR)
E-1	0.58	0 - 0%	0.58 - 100%	15.0	0.20	0.162	1.40	0.188	1.62	0.225	1.94	0.287	2.47
TOTAL	0.58	0 - 0%	0.58 - 100%			0.162	- 11 17	0.188	-	0.225	-	0.287	-
P-1	0.20	0.15 - 75%	0.05 - 25%	5.0	0.76	0.368	2.42	0.427	2.81	0.509	3.35	0.649	4.27
P-2	0.22	0.18 - 81%	0.04 - 19%	5.0	0.83	0.430	2.42	0.514	2.81	0.612	3.35	0.779	4.27
P-3	0.16	0.11 - 71%	0.05 - 29%	5.0	0.73	0.283	2.42	0.328	2.81	0.391	3.35	0.499	4.27
TOTAL	0.58	0.44 - 76%	0.14 - 24%			1.081	-	1.269	-	1.512	-	1.927	-
DIFFERENCE	-	-				0.919	_	1.081	-	1.287	<u>.</u>	1.640	_

Note: Participaton Intensity values are obtained from NOAA Atlas (https://hdsc.nws.noaa.gov/hdsc/pfds/pfds_map_cont.html).

Location information: Latitude: 38.6608° Longitude: -121.0012° Elevation: 1129.89 ft

LEGEND


DRAINAGE AREA

-∕--|> SURFACE WATER FLOW

DRAINAGE AREA ID/AREA

CONTOUR LINE BUILDING/SIDEWALK

PARKING PAVEMENT









PixelArch Itd.

Office: 24001 Calle De La Magdalena, unit 3896 Laguna Hills, CA 92653 Tel: (415) 316 7162 info@pixelarchltd.com www.pixelarchltd.com



KASSIS DEVELOPMENT
2580 COUNTRY CLUB DR, CAMERON PARK,
CA 95682

C6 **Drainage Area** Мар





STORM ANALYSIS - LINKS (25-YR STORM ANALYSIS)

	HEIGHT/TOP WIDTH OR DIAMETER (IN)	INLET INVERT ELEVATION (FT)	OUTLET INVERT ELEVATION (FT)	LENGTH (FT)	SLOPE (%)	FLOW CAPACIT (CFS)	Y PEAK FLOW (CFS)	MAX. VELOCITY (FT/SEC)
OPEN CHANNEL WEST	18/36	1135	1133	95	2.1	9.94	0.50	7.85
CULVERT AB	12	1135	1133	77	2.6	4.98	0.30	5.51
CULVERT BO	12	1133	1126	94	7.4	8.43	0.60	5.75
OPEN CHANNEL EAST	18/36	1138	1126	148	8.1	19.50	0.38	9.34

STORM ANALYSIS - INLETS

	RIM ELEVATION (FT)	INVERT ELEVATION (FT)	PEAK FLOW (CFS)	GUTTER FLOW DEPTH DURING PEAK FLOW
INLET-A	1135	1133	0.31	0.01 FT
INLET-B	1133	1131	0.61	0.11 FT
OUTLET	1129	1126	0.97	








PixelArch ltd.

Office: 24001 Calle De La Magdalena, unit 3896 Laguna Hills, CA 92653 Tel: (415) 316 7162



KASSIS DEVELOPMENT
2580 COUNTRY CLUB DR, CAMERON PARK,
CA 95682

Sea

WING TITLE

C8
Stormwater
Structures

Page No.:

